EXEMPLARY BUILDING PRE-CONSTRUCTION ENERGY STUDY FOR HOBSON PLACE SOUTH



Respectfully submitted to Seattle City Light by



7/12/2021

I. Summary and Project Description

Hobson Place South (HPS) is a new, permanent supportive housing (PSH) building project being developed by DESC in the Rainier Valley neighborhood of Seattle, WA. HPS is permitted as a 7-story addition to an existing building, Hobson Place North (HPN)¹. HPS includes 92 small efficiency dwelling units (SEDUs), PSH resident services at level L1, medical clinic space on L1, L2 and L3, and one level (P1) of below-grade enclosed parking garage. The project is designed to comply with the 2015 Seattle Energy Code (SEC), Washington State Department of Commerce's Evergreen Sustainable Development Standards (ESDS), and PHIUS+ 2018 (a.k.a "Passive House") certification for the PSH portion of the building. Electricity is the only fuel source used for HPS, and the PSH portion of the project is mastermetered separately from the HPS medical clinic and HPN.

As part of DESC's pursuit of the Housing Development Consortium's (HDC) Exemplary Building (EB) Program, O'Brien360 has completed this Pre-Construction Energy Study, as defined by Seattle City Light's (SCL) "Project-Specific Specifications for An Energy Analysis Assistance (EAA) Agreement". The purpose of this study is estimate site energy savings and costs for energy conservation measures (ECMs) included in the proposed design, as compared to a 2015 Seattle Energy Code (SEC) baseline design, as well as estimate to the annual energy use index (EUI), in kBtu/ft2/year. To qualify for SCL's EB incentives, the proposed design must be all-electric and comply with one of two criteria:

- a) Annual site EUI, not including renewables, of 20 kBtu/ft2/year or less.
- b) Annual site energy use is 40% less than the 2015 SEC baseline design, not including renewables.

The scope of the energy study is limited to the residential dwelling units on L4-L7 units and the associated residential circulation and support areas. Table 1 summarizes the floor areas of the project, and what areas are included in the model, while Appendix A has floor plan diagrams that highlight the extent of the model scope. Once HPS is built, there will be floor connections between it and HPN.

¹ The existing building, Hobson Place North, is constructed under permit #6617518-CN. Hobson Place South is constructed under permit #6707386-CN.

Space Type	Conditioned	Unconditioned	Notes
	Area (ft²)	Area (ft ²)	
Residential Apartments	32,045	0	92 SEDUs on levels 4-7
Residential Corridors	7,490	0	Corridors on levels 4-7
Residential Stairwell	3,427	0	Includes stairwells from L7 down to L1,
			excludes extension to P1
Residential Laundries	760	0	Laundry rooms on level 4-7
Residential Storage	597	0	Storage rooms on level 4-7
Other Residential Area	2,213	1,498	Unconditioned includes trash and mechanical
			rooms on L1. Conditioned areas include shafts.
Supportive Housing Area	5,360	0	All area and energy excluded from this analysis
(Level 1)			
Health Clinic (Levels 1-3)	26,375	0	All area and energy excluded from this analysis
Parking Garage (Entire	840	12,265	26 stalls for clinic staff use only. Bike storage
Level P1)			for residents and staff. All area and energy
			excluded from this analysis
TOTAL Building Areas	79,107	13,763	
TOTAL Model Areas	44,319	0	Modeled areas only include apartments,
	(Area Used to Calculate EUI)		corridors, stairwell, laundry and storage rooms.

Table	1. B	uilding	Floor	Areas

An eQUEST (v3.65.7174) model was developed using the HPS 1/14/2020 Bid Set drawings and specification with the 2/6/2020 Addendum 1 updates. The principal proposed HVAC system design is electric resistance (cove) heaters in the apartments, along with three, rooftop dedicated outdoor air systems (DOAS) with energy recovery, which provide balanced ventilation for both the dwelling units and the corridors.

2015 SEC envelope compliance was demonstrated using the Component Approach method and complying prescriptively with C406.8 (enhanced thermal envelope), and C406.9 (reduced air infiltration) options which have been reflected in the baseline design model. See description of ECMs A1.0 and A2.0 for how these options were accounted for in the baseline design model.

Table 2 summarizes the modeled baseline and proposed end-use and total annual EUIs, including and excluding the estimated energy produced by photovoltaics (PV). Table 3 lists the title, non-interactive, and interactive (proportionate) energy impact of each of the modeled ECMs. The EUIs are modeled assuming typical meteorological year (TMY3) conditions for the Seattle-Boeing Field weather station, with wind speed adjustment for the local terrain. ECM assumptions and analysis method are described further in Section II. As indicated in Table 1 above, the floor area used all EUI calculations included in the tables below is 44,319 ft².

Exemplary Building Pre-Construction Energy Study

Design (units = kBtu/ft2)	Interior Lights	Appl. + Misc.	Heating	Cooling	Pumps & Aux	Interior Fans	DHW	Total (Excl. PV)	PV	Total (Incl. PV)
Baseline	4.3	9.8	13.2	0.1	0.3	3.6	18.2	49.5	(0.3)	49.1
Proposed	3.1	9.0	0.4	0.1	0.7	3.5	3.2	20.0	(3.1)	16.9
Reduction	27%	8%	97%	16%	-121%	3%	83%	60%		66%

Table 2. Annual End-Use and Total EUI

	Estimated Annual Consumption					Estimated Anuual Savings					Incremental Costs						
ECM ID	ECM Description	Modeled Energy	Non-Modeled Energy	Total	Energy	EUI	Non-Int	eractive	Savings		Interactiv	e Savings			First	Simple Payback	Annual O&M
		kWh	kWh	kWh	MBtu	kBtu/ft2	MBtu	kWh	%	MBtu	kWh	\$/year	%		\$	years	\$/year
-	Baseline	372,537	269,785	642,322	2,192	49.5	-	-	0.0%	-	-	-	0.0%	\$	-		
A1.0	Thermally Improved Windows	357,321	269,785	627,106	2,140	48.3	52	15,216	2.4%	51	15,039	\$ 1,504	2.3%	\$	52,750	35	\$ -
A2.0	Reduced Air Leakage	370,123	269,785	639,908	2,183	49.3	8	2,414	0.4%	8	2,386	\$ 239	0.4%	\$	80,783	339	\$ -
E1.0	Reduced Int. Lighting Power	368,410	269,785	638,195	2,178	49.1	14	4,127	0.6%	14	4,079	\$ 408	0.6%	\$	-	0.0	\$ -
E2.0	Energy Star Refrigerators	371,203	269,785	640,988	2,187	49.3	5	1,334	0.2%	4	1,318	\$ 132	0.2%	\$	6,900	52	\$ -
E3.0	Energy Star Common Laundry	372,537	254,603	627,140	2,140	48.3	52	15,182	2.4%	51	15,005	\$ 1,500	2.3%	\$	-	0.0	\$ -
M1.0	ERV System	252,594	269,785	522,379	1,782	40.2	409	119,943	18.7%	404	118,545	\$ 11,854	18.5%	\$	577,879	49	\$ 4,400
M2.0	Thermostat w/ Window Switch	357,742	269,785	627,527	2,141	48.3	51	14,795	2.3%	50	14,623	\$ 1,462	2.3%	\$	12,200	8	\$ -
P1.0	Efficient Plumbing Fixtures	372,537	232,672	605,209	2,065	46.6	127	37,113	5.8%	125	36,680	\$ 3,668	5.7%	\$	-	0.0	\$ -
P2.0	Improved Plumbing Distribution	389,762	238,274	628,036	2,143	48.4	49	14,286	2.2%	48	14,119	\$ 1,412	2.2%	\$	30,500	22	\$ -
P3.0	Heat Pump Water Heater	372,537	106,963	479,500	1,636	36.9	556	162,822	25.3%	549	160,924	\$ 16,092	25.1%	\$	73,000	5	\$ 1,000
	Proposed (Not Incl. PV)	192,034	67,794	259,828	887	20.0	1,306	382,494	59.5%	1,306	382,718	\$ 38,272	60%	\$	834,012	21.8	\$ 5,400
	Proposed (Incl. PV)	192,034	27,794	219,828	750	16.9				1,442	422,494	\$ 42,249	66%	\$	910,259	21.5	

Table 3. ECM Summary Table

II. Energy Conservation Measures

ECM Descriptions

The sub-sections below summarize the following information for each of the ECMs included in the proposed design:

- A description of the proposed design ECM, and the corresponding baseline design assumptions.
- A description of how the ECM was analyzed.
- The estimated (modeled) energy savings of the ECM (kWh/year), as well as the first-year energy cost savings, assuming a blended utility rate of \$0.10/kWh. Energy and energy cost savings reported in these tables reflect the calculated <u>proportionate accounting of interactive effects</u>.
- The estimated <u>incremental</u> costs for the measure, as provided by the project general contractor, Walsh Construction Company (WCC), as well as the calculated simple payback in years. Also provided is the estimated <u>incremental</u> maintenance cost. Appendix C includes a table summarizing cost estimating notes and assumptions.
- A description of the ECMs influence on tenant satisfaction and building operations, such as
 indoor air quality, thermal comfort, usability, durability, reliability, ease of maintenance, and
 maintenance cost, <u>as they compare to the baseline system</u>. A qualitative assessment, on a scale
 of -5 to +5 for each attribute is provided, with 0 being neutral, -5 being a very negative impact,
 and +5 being a very positive impact.

ECM Results Summary

Table 4 at the end of this section summarizes the ECMs, including energy consumption and cost savings (both non-interactive and proportionate accounting of interactive effects), estimated incremental first cost/simple payback, and estimated incremental annual maintenance cost. For each run, the DOE-2.2 Building Energy Performance Summary (BEPS) report for each run has been included in Appendix C.

//12/2021	7/	1	2/	2	0	2	1
-----------	----	---	----	---	---	---	---

A1.0 – Thermally Improved Windows

		Proposed	Baseline						
ECM Description	Triple-pane vir 0.18). These window improvements result in the pr 'Component A than code. Thi for SEC C406.8	nyl windows (U-0.18, SHGC- s, as well as other to the thermal envelope, roposed UA (per the SEC pproach') being 18% better s exceeds the requirement 3.	Double-pane vinyl windows (U-0.26, SHGC-0.18). These windows, and assuming other components of the baseline envelope are modeled the same as the proposed, the baseline design UA is 15% better than code. This minimally satisfies the requirement for C406.8.						
How Measure Was Analyzed	Constructions the interior and method. L4 flo Dwelling unit t and baseline.	Constructions modeled using 'Layers' specification method, with mass assumed only for the interior and exterior sheathing. Windows modeled using 'Simplified' specification method. L4 floor is adiabatic since it is over conditioned space that is not modeled. Dwelling unit thermostat setpoint of 70F, assumed to be the same in both the proposed and baseline.							
Annual kWh/Cost Savings	15,039 kWh \$1,504/year								
Inc. First Cost / Simple Payback	\$52,750 / 35 years								
Maintenance Cost		\$0/	year						
Operational Impacts	Rating (-5 to +5)		Comments						
Indoor Air Quality	0	No anticipated impact for th	is measure.						
Thermal Comfort	+5	The proposed envelope, in particular the windows, have low thermal transmittance. This is expected to increase the mean radiant temperature of the apartments, and therefore result in the space feeling "warmer". This should translate to lower thermostat setpoints needed to maintain the same comfort level, however, the proposed and baseline space temperature setpoints were assumed the same for this measure.							
Usability	0	No anticipated impact for th	is measure.						
Reliability	0	No anticipated impact for th	is measure.						
Ease of Maintenance	0	No anticipated impact for th	is measure.						
Maintenance Cost	0	No anticipated impact for this measure.							

A2.0 – Reduced Air Leakage

		Proposed	Baseline					
	Air leakage is (0.08 cfm/ft2 of envelope	Air leakage is 0.25 cfm/ft2 of envelope					
	enclosure area	@ 0.3 in. H2O.	enclosure area @ 0.3 in. H2O.					
ECM Description	This satisfies F	PHIUS+ 2018 requirements,	This minimally satisfies the requirement					
	and substantia	Ily exceeds the requirement	for SEC C406.8.					
	for SEC C406.8	3.						
	The tested lea	sted leakage rate was then converted to a "natural" infiltration rate at 10 mph						
	multiplying the	test value by 0.115, per PNNL	² . The natural infiltration rate was modeled					
	using the 'AIR-	CHANGE' method, with the in	filtration only assumed to occur in					
How Measure Was	apartments zo	nes. In addition, to account for	the observation that many occupants have					
Analyzed	the windows o	pen throughout the year, both	the proposed and baseline models include					
	and an additio	nal, constant 0.05 cfm/ft2 infil	tration for each apartment. This estimate					
	assumes rough	nly half the apartments have th	ne awning apartment window opened 2" or					
	more.	more.						
Annual kWh/Cost	2.386 kWh \$220 / year							
Savings	2,300 KVVII \$239/ year							
Inc. First Cost /	\$80 783 / 339 vears							
Simple Payback		φου, 100 / 009 years						
Maintenance Cost		\$0/	year					
Operational Impacts	Rating		Comments					
•	(-5 to +5)							
Indoor Air Ouality	+3	This measure helps ensure t	he influence on building air leakage on					
~ · ·		mechanically balanced venti	lation flows is decreased.					
Thermal Comfort	+1	Reducing infiltration reduces	s heating loads and ensures balanced					
		ventilation system works as	intended.					
Usability	0	No anticipated impact for thi	is measure.					
Reliability	0	No anticipated impact for thi	is measure.					
		Since the air and weather ba	arrier for the exterior walls are the same					
Fase of Maintenance	+5	layer, an air barrier that has	better design details and field inspection					
	FJ	and should translate to less	water infiltration, which should increase the					
		lifespan of the building envelope.						
Maintenance Cost	0	No anticipated impact for this measure.						

² PNNL Report 18898, Infiltration Modeling Guidelines for Commercial Building Energy Analysis (2009)

E1.0 – Reduced Interior Lighting Power

		Propos	sed		Baseline			
	The average sp	bace light	ing power is	as	The average space lig	ghting power ar	re the	
	designed, sum	marized l	pelow based	allowances defined by Table C405.4.2(2).				
	lighting fixture	and area	take-offs. T	he	Summarized in the ta	ble below.		
	proposed is on	average	37% less tha	an the				
	baseline.							
FCM Description	Space Type		(W/ft²)		Space Type	(W/ft²)		
ECIM Description	Corridor		0.263		Corridor	0.480		
	Stairwell		0.398		Stairwell	0.500		
	Laundry room	า	0.349		Laundry room	0.430		
	Trash room		0.318		Trash room	0.680		
	Storage room		0.349		Storage room	0.450		
	Mechanical re	oom	0.597		Mechanical room	0.680		
	Lighting is defi	ned as a	sensible loa	d in the s	space that it occurs. Lig	ghting schedule	es for	
	corridor, stairw	vells, and	laundry roor	n are 24/	'7, other spaces assum	ed to be 854 hi	rs per	
How Mossuro Was	year. For both the proposed and baseline design, stairwell, laundry room, and storage							
Applyzod	room lighting power are reduced to account for code-required occupancy sensors							
Analyzeu	(stairwells = 35% reduction, 10% for other spaces). Dwelling unit lighting power is							
	assumed the same in the proposed and baseline design, 0.6 W/ft2, and on for 2.34 full							
	load hours per	day.						
Annual kWh/Cost			4 07	9 kWh	\$408/vear			
Savings			7,07	5 10011				
Inc. First Cost /				\$	0			
Simple Payback				Ψ	•			
Maintenance Cost				\$0/	year			
Operational Impacts	Rating				Commonto			
Operational impacts	(-5 to +5)				Comments			
Indoor Air Quality	0	No anti	cipated impa	act for thi	is measure.			
Thermal Comfort	0	No anti	cipated impa	act for thi	is measure.			
Usability	0	No anti	cipated impa	act for thi	is measure.			
Reliability	0	No anti	cipated impa	act for thi	is measure.			
Ease of Maintenance	0	No anti	cipated impa	act for thi	s measure.			
Maintenance Cost	+5	Fewer l replace	ight fixtures d in the futu	translate re.	es to fewer fixtures that	t will need to be	e	

E2.0 – Energy Star Refrigerators

		Proposed	Baseline					
ECM Description	The proposed GE model GPE energy use of 3	refrigerator is Energy Star, 12FGK, which has a rated 310 kWh/year	The baseline refrigerator is non-Energy Star and assumed to meet federal minimum requirement for the given size, 347 kWh/year.					
How Measure Was Analyzed	Refrigerator er modeled as 10	Refrigerator energy use is converted to an average W/ft2 of apartment area, and modeled as 100% sensible load distribute evenly across all hours of the year.						
Annual kWh/Cost Savings	1,318 kWh \$132/year							
Inc. First Cost / Simple Payback	\$6,900 / 52 years							
Maintenance Cost		\$0/	year					
Operational Impacts	Rating (-5 to +5)		Comments					
Indoor Air Quality	0	No anticipated impact for th	is measure.					
Thermal Comfort	+2	A more efficient refrigerator thermal comfort in the sumn	adds less heat to the space, which improves ner.					
Usability	0	No anticipated impact for th	is measure.					
Reliability	0	No anticipated impact for th	is measure.					
Ease of Maintenance	+3	DESC has specified this same refrigerator for most of its other new properties, so using the same model makes it easier to maintain.						
Maintenance Cost	0	No anticipated impact for th	is measure.					

		Proposed	Baseline					
ECM Description	The propose (2 per reside and are estir Washer: 0.16 Dryer: 3.0 kV	d common washer/dryer pairs ntial floor) are Energy Star, nated to use: 6 kWh/cycle, 2.7 gal HW/cycle Vh/cycle	The baseline washer/dryers are non-Energy Star, same quantity as the proposed, and are estimated to use: Washer: 0.15 kWh/cycle, 10.3 gal HW/cycle Dryer: 4.0 kWh/cycle					
How Measure Was Analyzed	1.5 wash & d design, base consumption ACEEE studi assumed to l DHW plant lo	1.5 wash & dry cycles/apartment/week are assumed for both the proposed and baseline design, based on DESC laundry vendor data obtained for a previous project. Energy consumption and hot water consumption for the proposed and baseline design is based on ACEEE studies. ^{3,4} Washer/dryer energy use is assigned to laundry rooms, with 100% assumed to be exhausted from the building. Laundry hot water loads are added to the DHW plant load.						
Annual kWh/Cost Savings	15,005 kWh \$1,500/year							
Inc. First Cost / Simple Payback		Ş	\$0					
Maintenance Cost		\$0/	year					
Operational Impacts	Rating (-5 to +5)		Comments					
Indoor Air Quality	0	No anticipated impact for this	measure.					
Thermal Comfort	+1	A more efficient washing syste improves thermal comfort in th	m results in less heat to the space, which e summer.					
Usability	0	No anticipated impact for this	measure.					
Reliability	0	No anticipated impact for this	measure.					
Ease of Maintenance	0	No anticipated impact for this	measure.					
Maintenance Cost	0	No anticipated impact for this	measure.					

E3.0 – Energy Star Common Laundry

³ <u>High-Performance, Coin-Operated Clothes Washer Demonstration and Evaluation</u> (2002)

⁴ Are We Missing Energy Savings in Clothes Dryers? (2010)

		Proposed	Baseline				
ECM Description	Innee rootop Ervs (Swegon Gold RX)Each apartment has a whole houseserving dwelling units, corridors and trashexhaust fans, operating continuouslyrooms. Design target is 50 cfm supply/60same dwelling unit exhaust rate as thcfm exhaust per apartment. Trash/janitorproposed (4,600 cfm), fan power = 0.room exhaust = 700 cfm. TotalW/cfm. Make-up air by via trickle versupply/exhaust air flow = 6,620 cfm. (seeCorridor ventilated by rooftop air hanmechanical schedules for individual unitwith electric heat, same supply flowERV values). ERV has net sensibleproposed (1,260 cfm), MERV 13 supplyefficiency 85%; no preheat coil, MERV 13filters, fan power = 0.50 W/cfm of susupply filters, fan power = 0.78 W/cfm offan, 700 cfm, 0.30 W/cfm. Local kitcheboth supply flow. Local kitchen exhaustfan, 700 cfm, 0.30 W/cfm. Local kitchby ERV and recirculating range hood.exhaust by range hood ducted to exter						
How Measure Was Analyzed	The proposed ERV is modeled as one multizone HVAC system with the specified fan power and heat recovery effectiveness, serving both the dwelling units and corridor. It operates continuously at the proposed design ventilation rate. Heating in dwelling units modeled as baseboard heats, with a constant setpoint of 70F. The baseline apartment ventilation is modeled as a continuously operated zone exhaust fan, with specified fan power and same outside air supply flow rate as the proposed. Make-up air calculated by the program as the quadratic sum with infiltration flow. The baseline corridor ventilation system is modeled as a 100% OA packaged single zone system with electric heat, operating continuously with the same supply ventilation as proposed. Heating in dwelling units modeled the same as the proposed. Intermittent range hood flow and fan power modeled the same in both the proposed and baseline model.						
Annual kWh/Cost Savings		118,545 kWh	\$11,854/year				
Inc. First Cost / Simple Payback		\$577,879	/ 49 years				
Maintenance Cost		\$4,40	0/year				
Operational Impacts	Rating (-5 to +5)		Comments				
Indoor Air Quality	+5	Balanced ventilation provide air is filtered to MERV 13.	s better ventilation effectiveness, and supply				
Thermal Comfort	+5	Reduced drafts at windows of	due to balanced pressurization.				
Usability	0	No anticipated impact for th	is measure.				
Reliability	+5	System is					
Ease of Maintenance	+3	System is centralized, so sim integrated into control system	nple to replace filters and ERVs can be m to alert building operations if not working.				
Maintenance Cost	-3	Maintenance costs include regular maintenance of central ERVs, and annual replacement of charcoal filters for recirculation hoods.					

M1.0 – Energy Recovery Ventilation (ERV) System

M2.0 – Thermostat with Window	/ Switch
-------------------------------	----------

		Proposed	Baseline						
ECM Description	Apartments ha by a line voltag Watcher (WR2 thermostat inc connected to n which when th window is oper automatically s to 60F. This is infiltration rate 0.25 cfm/ft2 @	ve cove heaters controlled ge thermostat, King Window 30-B) or equivalent. This ludes a dry contact that is nagnetic window switch, e contact is open (i.e. n), the thermostat sets back the heat setpoint anticipated to Proposed e for this individual ECM is 9 75Pa.	The baseline is the same as the proposed except windows do not have a magnetic switch installed and therefore the cove heater thermostat does not setback when the window is open. To account for the lack of heater setback it is assumed that roughly half the apartments have the awning apartment windows opened 2" or more.						
How Measure Was Analyzed	For both the pr 70°F. For the b the baseline in apartment. The proposed and l	roposed and baseline, the ther aseline, To account for the lac cludes an additional, constant e tested envelope air leakage r baseline designs.	mostat setpoint is assumed to be constant, of a window switch and open windows, 0.05 cfm/ft2 infiltration modeled for each ate is assumed to be the same for both the						
Annual kWh/Cost		14.623 kWh \$1.462/vear							
Savings									
Simple Payback		\$12,200	/ 8 years						
Maintenance Cost		\$0/	year						
Operational Impacts	Rating (-5 to +5)		Comments						
Indoor Air Quality	0	No anticipated impact for thi	s measure.						
Thermal Comfort	-3	Apartments will be colder if intended to encourage tenar understand or agree, they m	the windows are left open. This measure is its to keep windows closed, but if they don't ay complain about poor thermal comfort.						
Usability	0	The thermostat use by itself manner as a thermostat stat	f is operated by the tenant in a similar w/o a window switch.						
Reliability	-3	This system has a magnetic switch and may need adjustment if windows/building frame shifts over time.							
Ease of Maintenance	-3	The thermostat maintenance itself is similar to ones w/o switches, however, die to reliability and thermal comfort issues noted above, maintenance personnel should expect some questions/complaints unti tenants understand why they can't keep the apartment warm <u>and</u> the windows are open.							
Maintenance Cost	-3	Cost for replacing thermosta damaged by tenant, there ar	t is higher than normal, and if switch is e costs to replace it.						

		Proposed	Baseline							
	Plumbing fixtu	ure rated flow rates:	Code-maximum fixture rated flow rates:							
	Showerhead:	Showerhead: 1.50 gal/min Showerhead: 2.50 gal/min								
FCM Description	Lavatory fauc	et: 1.50 gal/min	Lavatory faucet: 2.20 gal/min							
Lew Description	Kitchen fauce	t: 1.80 gal/min	Kitchen faucet: 2.20 gal/min							
	Total estimate	ed hot water use: 23.6	Total estimated hot water use: 31.1							
	gal/apt/day		gal/apt/day							
	The proposed	daily DHW use is based on sub	b-meter data for another DESC project that							
	uses low-flow	r fixtures. The baseline consum	ption was estimated using the same							
	duration and i	number of fixtures uses as the I	proposed, but assuming standard flow							
	plumbing fixtu	ures. The baseline DHW deman	d was calculated using the formula from the							
How Measure Was	Energy Star N	Iultifamily Simulation Guideline	s^5 , using the proposed target flow from							
Analyzed	submetering o	data, and solving for the baselir	ne:							
/maryzea	ProposedHWDemand = BaselineHWDemand*(0.36+0.54*LFS/2.5+0.1*LFF/2.2)									
	Where:									
	LFS(gpm) = rated flow rate of the low-flow showerheads specified on the drawings									
	LFF(gpm)) = rated flow rate of the low-flow	ow faucets specified on the drawings							
	The loads we	re then input into the model of	the DHW plant (see ECM P3.0 description).							
Annual kWh/Cost		36 680 kWh	\$3.668/vear							
Savings										
Inc. First Cost /		\$	0							
Simple Payback		¥	~ 							
Maintenance Cost		\$0/	year							
Operational Impacts	Rating		Commonts							
Operational impacts	(-5 to +5)		Comments							
Indoor Air Quality	0	No anticipated impact for this	s measure.							
Thermal Comfort	0	No anticipated impact for this	s measure.							
Usability	0	No anticipated impact for this	s measure.							
Reliability	0	No anticipated impact for this	s measure.							
Ease of Maintenance	0	No anticipated impact for this	s measure.							
Maintenance Cost	0	No anticipated impact for this measure.								

P1.0 – Efficient Plumbing Fixtures

⁵ Energy Star Multifamily High Rise Program Simulation Guidelines, <u>Version 1.0, Revision 03 January 2015</u>

P2.0 – Improved Plumbing Distribution

		Proposed	Baseline							
	Proposed resid	lential plumbing distribution	Typical residential plumbing distribution							
	design:		design:							
	- One DHW/D	CW riser serving two apts	- One DHW/DCW riser serving every stack							
	where it is pos	sible (17 total risers).	of apartments (24 total risers).							
ECM Description	- Additional pip	pe insulation:	- Code-minimum pipe insulation:							
ECIM Description	Hot water distr	ribution on L4-7 (120F):	Hot water distribution on L4-7 (120F):							
	1" and smaller	: 2.0" thick	1" and smaller: 1.0" thick							
	1½" and larger	: 2.5" thick	$1\frac{1}{2}$ " and larger: 1.5" thick							
	Piping from DH	HW plant on P1 to L4 (140F):	Piping from DHW plant on P1 to L4 (140F):							
	1½ to 4: 3.0" th	nick	1½ to 4: 1.5" thick							
	The lengths of	the HW piping system was me	easured from piping diagrams. Heat loss for							
	the various len	gths and diameters was estim	ated using the 3EPlus software ⁶ . The							
How Measure Was	calculated hea	t loss was doubled to better al	ign with expected value of 80 watts of heat							
Analyzed	loss/apt, as observed for a similar, recently built DESC PSH project. The heat los									
	added as main	tenance heater load (see ECN	1 3.0 description), and distributed as heat							
	input in apartm	nput in apartment spaces of the energy model. See Appendix B for calculations.								
Annual kWh/Cost		$14110\text{kWb} \mid \text{\$1}412\text{km}$								
Savings		14,113 KVVII	ψ1,412 / year							
Inc. First Cost /		\$30,500 /	22 years							
Simple Payback		φ30,300 /								
Maintenance Cost		\$0/	year							
	Rating		0							
Operational Impacts	(-5 to +5)		Comments							
Indoor Air Quality	0	No anticipated impact for th	is measure.							
Thormal Comfort	13	Reducing DHW distribution losses helps reduce over-heating in the								
	τJ	summer.								
Usability	0	No anticipated impact for this measure.								
Reliability	0	No anticipated impact for th	is measure.							
Ease of Maintenance	0	No anticipated impact for th	is measure.							
Maintenance Cost	0	No anticipated impact for th	is measure.							

⁶ <u>3E Plus Software</u> developed by the North American Insulation Manufacturers Association (NAIMA).

P3.0 – Heat Pump Water Heater

	Proposed	Baseline
	The proposed DHW plant is located on P1	The baseline DHW plant is assumed to use
	and consists of:	the same design as the proposed with the
	- (10) Sanden CO2 heat pumps (HPs),	following exceptions:
	located on the wall of the parking garage.	- Instead of CO2 HPs, the hot water is
	- (2) 504 gal storage tanks w/ R-16	heated at the plant by electric resistance
	insulation and a 27 kW electric resistance	heaters, with an equivalent heating
	back-up heater, located in the P1	capacity as the (10) Sanden HPs (45 kW).
	mechanical room.	- Storage tank insulation is code-minimum
	- An 8 kW electric resistance temperature	R-12.5.
ECM Description	maintenance water heater and electronic	
	TMV in a mechanical room on L4.	
	Hot water is generated and stored in the	
	P1 tanks at 140F. The water is piped to a	
	storage room on L4, and then mixed with	
	cold/recirc water and supplied to building	
	at 120F. Hot water is circulated through	
	distribution on L4-7, but is not recirculated	
	back to the plant on P1.	
	An hourly simulation of the plant was develo	ped using a spreadsheet. The model
	accounts for:	
	- Hot water loads, varying on a daily basis us	ing the average load profile developed from
	how water sub-metering data from another [DESC PSH project.
	- Hourly environmental temperature for the H	IP evaporators and storage tanks. This is
	conservatively assumed to be the same as th	e ambient air temperature, as the parking
	garage should typically be warmer than the a	ambient air temperature.
11 M W	- Efficiency as a function of environmental te	emperature for the Sanden heat pump.
How weasure was	- Monthly variation in temperature of munici	pal make-up water.
Analyzed	- Storage tank stratification and heat losses.	
	- Distribution losses from piping system, whi	ch adds to the total hot water heating
	energy load.	
	- Circulation pump input energy and pump he	eat gain to recirculation system.
	- Defrost cycles of CO2 HPs (assumed to be	every hour when environmental temp is
	<40F, and reducing hourly COP by 20%).	
	See Appendix B for a view copy of the model	inputs and outputs for the first 4 days of
	8760 simulation.	
Annual kWh/Cost	160.924 kWh	\$16.092 /vear
Savings		. , , ,
Inc. First Cost /	\$73.000	/ 5 years
Simple Payback	·	-
Maintenance Cost	\$1000)/year

Operational Impacts	Rating (-5 to +5)	Comments					
Indoor Air Quality	0	No anticipated impact for this measure.					
Thermal Comfort	0	No anticipated impact for this measure.					
Usability	-3	The HPs					
Reliability	-3	HPs have more moving parts than electric resistance water heaters. However, the refrigeration circuit of the Sanden HPs is not field serviceable, and is relatively easy to replace.					
Ease of Maintenance	-3	There are 10 individual HPs, as well as one electric water heater that must be maintained.					
Maintenance Cost	-3	Maintenance costs are anticipated to be higher than electric resistance water heaters.					

Solar PV

		Proposed	Baseline							
ECM Description	40.0 kW solar I the L7 roof.	PV system, oriented south on	C411.1 required PV system, 4.0 kW							
How Measure Was	The C411.1 red	quired PV system is based on T	70 W/ft2 for the five largest building levels							
Analyzed	(56,890 ft2). El	ectricity production was estim	ated assuming 1000 kWh/kW.							
Annual kWh/Cost		36 000 kWh	\$3.600 /vear							
Savings										
Inc. First Cost /		\$76,274 / 21 years								
Simple Payback	(No production degradation is assumed in the simple payback calculation)									
Maintenance Cost		\$0/	year							
Operational Impacts	Rating		Comments							
	(-5 t0 +5)									
Indoor Air Quality	0	No anticipated impact for the	is measure.							
Thermal Comfort	0	No anticipated impact for th	is measure.							
Usability	0	No anticipated impact for th	is measure.							
Reliability	0	No anticipated impact for th	is measure.							
Ease of Maintenance	0	No anticipated impact for th	is measure.							
Maintenance Cost	0	No anticipated impact for this measure.								

ECM Results Summary

Estimated Anuual Consumption					Estimated Anuual Savings							Incremental Costs					
ECM ID	ECM Description	Modeled Non-Modeled Total Energy		Energy	EUI Non-Interactive Savings					Firs	t	Simple Payback	Annual O&M				
		kWh	kWh	kWh	MBtu	kBtu/ft2	MBtu	kWh	%	MBtu	kWh	\$/year	%	\$		years	\$/year
-	Baseline	372,537	269,785	642,322	2,192	49.5	-	-	0.0%	-	-	-	0.0%	\$	-		
A1.0	Thermally Improved Windows	357,321	269,785	627,106	2,140	48.3	52	15,216	2.4%	51	15,039	\$ 1,504	2.3%	\$5	2,750	35	\$ -
A2.0	Reduced Air Leakage	370,123	269,785	639,908	2,183	49.3	8	2,414	0.4%	8	2,386	\$ 239	0.4%	\$ 8	0,783	339	\$ -
E1.0	Reduced Int. Lighting Power	368,410	269,785	638,195	2,178	49.1	14	4,127	0.6%	14	4,079	\$ 408	0.6%	\$	-	0.0	\$ -
E2.0	Energy Star Refrigerators	371,203	269,785	640,988	2,187	49.3	5	1,334	0.2%	4	1,318	\$ 132	0.2%	\$	6,900	52	\$ -
E3.0	Energy Star Common Laundry	372,537	254,603	627,140	2,140	48.3	52	15,182	2.4%	51	15,005	\$ 1,500	2.3%	\$	-	0.0	\$ -
M1.0	ERV System	252,594	269,785	522,379	1,782	40.2	409	119,943	18.7%	404	118,545	\$ 11,854	18.5%	\$ 57	7,879	49	\$ 4,400
M2.0	Thermostat w/ Window Switch	357,742	269,785	627,527	2,141	48.3	51	14,795	2.3%	50	14,623	\$ 1,462	2.3%	\$ 1	2,200	8	\$ -
P1.0	Efficient Plumbing Fixtures	372,537	232,672	605,209	2,065	46.6	127	37,113	5.8%	125	36,680	\$ 3,668	5.7%	\$	-	0.0	\$ -
P2.0	Improved Plumbing Distribution	389,762	238,274	628,036	2,143	48.4	49	14,286	2.2%	48	14,119	\$ 1,412	2.2%	\$ 3	0,500	22	\$ -
P3.0	Heat Pump Water Heater	372,537	106,963	479,500	1,636	36.9	556	162,822	25.3%	549	160,924	\$ 16,092	25.1%	\$ 7	3,000	5	\$ 1,000
	Proposed (Not Incl. PV)	192,034	67,794	259,828	887	20.0	1,306	382,494	59.5%	1,306	382,718	\$ 38,272	60%	\$ 83	4,012	21.8	\$ 5,400
	Proposed (Incl. PV)	192,034	27,794	219,828	750	16.9				1,442	422,494	\$ 42,249	66%	\$ 91	0,259	21.5	

Table 4. ECM Results Summary

Hobson Place South

Exemplary Building Pre-Construction Energy Study

ECM ID	ECM Description	Interior Lights	Plug Loads	Space Heat	HP Aux	Space Cool	Heat Rej	Pumps & Aux	Interior Fans	Laundry	DHW	Exterior Lights	Total	EUI	Savings
		MBtu	MBtu	MBtu	MBtu	MBtu	MBtu	MBtu	MBtu	MBtu	MBtu	MBtu	MBtu	kbtu/ft2	Mbtu
	Baseline	189.9	333.1	584.8	-	3.7	-	13.3	159.9	101.9	805.5	-	2,192	49.5	-
A1.0	Thermally Improved Windows	189.9	333.1	533.3	-	3.7	-	13.3	159.5	101.9	805.5	-	2,140	48.3	52
A2.0	Reduced Air Leakage	189.9	333.1	576.6	-	3.7	-	13.3	159.8	101.9	805.5	-	2,184	49.3	8
E1.0	Reduced Int. Lighting Power	139.4	333.1	621.3	-	3.7	-	13.3	159.9	101.9	805.5	-	2,178	49.1	14
E2.0	Energy Star Refrigerators	189.9	321.5	591.8	-	3.7	-	13.3	160.0	101.9	805.5	-	2,188	49.4	5
E3.0	Energy Star Common Laundry	189.9	333.1	584.8	-	3.7	-	13.3	159.9	77.6	778.0	-	2,140	48.3	52
M1.0	ERV System	189.9	333.1	163.9	-	3.2	-	29.4	155.9	101.9	805.5	-	1,783	40.2	409
M2.0	Thermostat w/ Window Switch	189.9	333.1	534.9	-	3.7	-	13.3	159.4	101.9	805.5	-	2,142	48.3	50
P1.0	Efficient Plumbing Fixtures	189.9	333.1	584.8	-	3.7	-	13.3	159.9	101.9	678.9	-	2,066	46.6	127
P2.0	Improved Plumbing	189.9	333.1	643.0	-	3.7	-	13.3	160.5	101.9	698.0	-	2,143	48.4	49
P3.0	Heat Pump Water Heater	189.9	333.1	584.8	-	3.7	-	13.3	159.9	101.9	249.8	-	1,637	36.9	556
	Proposed (Not Incl. PV)	139.4	321.5	19.5	-	3.1	-	29.4	155.9	77.6	140.4	-	887	20.0	1,305

Table 5. ECM End Use Energy Summary

**values in blue are the results calculated outside of eQUEST.*

III. Analysis of Overall Project

Results

Table 6 summarizes the end-use and total site EUIs for the project, as well as savings. The estimated annual EUI, before accounting for PV, is 19.1.

Design (units = kBtu/ft2)	Interior Lights	Appl. + Misc.	Heating	Cooling	Pumps & Aux	Interior Fans	DHW	Total (Excl. PV)	PV	Total (Incl. PV)
Baseline	4.3	9.8	13.2	0.1	0.3	3.6	18.2	49.5	(0.3)	49.1
Proposed	3.1	9.0	0.4	0.1	0.7	3.5	3.2	20.0	(3.1)	16.9
Reduction	27%	8%	97%	16%	-121%	3%	83%	60%		66%

Table 6. Annual End-Use and Total EUI

Figure 1 demonstrates the fraction of energy use by each end-use.



Figure 1. Annual Energy Fractions by End-use

Figure 2 plots the monthly electricity consumption by month.



Figure 2. Monthly Energy Consumption

Discussion

The proposed design energy savings, with respect to the 2015 SEC baseline and before accounting for on-site PV, is **60%**. The estimated annual EUI is **20.0** kBtu/ft2/year, and therefore the HPS design complies with both criteria laid out in SCL's Exemplary Building incentive program. The largest reduction in energy use occurs in the space heating and DHW end-use categories. Space heating is reduced primarily by using energy recovery, but also by load reduction measures, such as triple-pane windows, reduced air leakage, and use of a window switch to help encourage tenants to keep windows closed when it is cold outside. DHW energy use is reduced primarily by using high-efficiency CO2 heat pumps, though load reduction measures such as low-flow fixtures and improved plumbing distribution reduce loads, and therefore reduce the capacity of heat pumps required.

There are several efficiency measures that, in recent years, have become low/no-cost measures to implement. These include reducing interior lighting power, Energy Star common laundry equipment, and low-flow plumbing fixtures. With the exception of laundry equipment, the 2018 SEC and Washington State appliance standards⁷ largely codify these common measures by reducing lighting power allowances further and requiring all plumbing fixtures to be more efficient.

⁷ Washington State Department of Commerce. Appliance Standards

Life Cycle Cost Analysis

A LCCA was prepared using the Washington State Office of Financial Management (OFM) tool⁸. The construction costs entered in the tool are based on estimates for the baseline and proposed designs prepared by the general contractor, Walsh Construction. In most cases, the LCCA includes a line item entry of sub-category costs when they differ between the proposed and base case designs. Where costs were assumed to be the same between the two designs, costs were rolled up and entered under the primary categories. In addition to differences in first cost, differences in expected useful life (EUL) and maintenance costs were estimated when possible.

Figure 3 presents the executive report from the LCCA tool for the following three cases:

- 1. <u>Baseline:</u> 2015 SEC Baseline described in this report, including C406.3, C406.8, and C411 minimum PV required
- <u>Alt. 1:</u> Proposed Exemplary Building/PHIUS+ 2018 design, including as designed PV. Sales tax for additional energy efficiency measures and the projected minimum SCL rebate of \$3,500/apartment has been included.
- 3. Alt. 2: Same as Alt 1., but adding additional soft costs anticipated for the proposed design.

The LCCA analysis indicates the proposed UHEE design has a positive net present savings (NPS) both before <u>and</u> after accounting for the social cost of carbon dioxide emission over the 50 year LCCA time horizon.

⁸ LCCA tool Version 2019-A, provided to the Hobson Place project team for the 2019 Housing Trust Fund UHEE application

Office of Financial Management Olympia, Washington - Version: 2019-A Life Cycle Cost Analysis Tool

Executive Report

Project Information							
Project:	DESC Hobson Place - South						
Address:	1911 22nd Ave S, Seattle, 98144						
Company:	O'Brien360						
Contact:	David Reddy						
Contact Phone:	206-406-9856						
Contact Email:	david@OBrien360.com						

Key Analysis Var	Building Cha	aracteristics	
Study Period (years)	50	Gross (Sq.Ft)	44,319
Nominal Discount Rate	3.11%	Useable (Sq.Ft)	44,319
Maintenance Escalation	1.00%	Space Efficiency	100.0%
Zero Year (Current Year)	2021	Project Phase	0
Construction Years	0	Building Type	0

Life Cycle Cost Analysis				BEST			
Alternative		Baseline		Alt. 1		Alt. 2	
Energy Use Intenstity (kBtu/sq.ft)		49.1		16.9	16.9		
1st Construction Costs	\$	16,299,771	\$	17,480,013	\$	17,634,805	
PV of Capital Costs	\$	16,210,897	\$	17,961,630	\$	18,116,422	
PV of Maintenance Costs	\$	-	\$	344,656	\$	344,656	
PV of Utility Costs	\$	3,502,973	\$	1,205,139	\$	1,205,139	
Total Life Cycle Cost (LCC)	\$	19,713,870 \$ 19,511,425				19,666,217	
Net Present Savings (NPS)		N/A	\$	202,444	\$	47,652	
ocietal LCC takes into consideration the s	ocial co	ost of carbon dioxide	emi	ssions caused by opera	ntior	al energy consumption	
(GHG) Social Life Cycle Cost				BEST			
GHG Impact from Utility Consumption		Baseline		Alt. 1		Alt. 2	
Tons of CO2e over Study Period		13,144		4,522		4,522	
% CO2e Reduction vs. Baseline		N/A		66%		191%	
Present Social Cost of Carbon (SCC)	\$	1,414,732	\$	486,715	\$	486,715	
Total LCC with SCC	\$	21,128,601	\$	19,998,140	\$	20,152,932	
NPS with SCC		N/A	\$	1,130,461	\$	975,669	





Figure 3. LCCA Executive Report

Parking Garage Energy

Table 7 summarizes the estimated parking garage ventilation and lighting energy for the project.

Parking Garage Floor Area	10,996 ft2
Lighting	
Design Power Density	1.143 kW (~0.104 W/ft2)
Annual Operating Hours	8,760 hours
Controls	Occupancy sensor (OS) controls for 50% of the
	lighting, assume controlled lights are off for 50%
	of the time. 25% net reduction in lighting energy
	use.
Estimated Annual Energy Use	7,513 kWh
Ventilation	
Design Exhaust Flow Rate	8,300 cfm
Design Exhaust Fan Power	1.58 BHP (~0.16 W/cfm)
Annual Operating Hours	8,760 hours
Controls	Carbon monoxide (CO) controls for variable speed
	fans. 87.5% reduction in fan energy.
Estimated Annual Energy Use	1,454 kWh

Table 7. Parking Garage Energy

IV. Post-Construction Monitoring Recommendations

Post-construction monitoring has been discussed throughout the project. One asset the HPS project has that most other multifamily projects do not is a central building automation system (BAS). That system will monitor and/or control the residential ERVs, the Sanden heat pump plant, and other equipment in the building outside the scope of this study. Additionally, separate energy and water metering systems are being installed, providing 15 minute or less interval measurement of residential apartment hot/cold water and electricity. There is currently no central monitoring capability associated with the residential apartment indoor air quality, temperature, or window switch operation, though there is a promising new product available from King Electric that would provide at minimum temperature and window switch operation. The following is a list recommended post-occupancy evaluations.

ERVs

The Swegon Gold RX ERV's used for this project are high-efficiency, Passive House certified units. Mechanical Sales, the local Swegon rep, and O'Brien360 have been facilitating a study of the ERVs and apartment indoor air quality as part of a larger study that compares the performance of the ERV systems used in HPS and Hobson Place North (HPN). HPN, the first phase of Hobson Place construction, with 85 apartments, also utilizes heat recovery for the apartment ventilation systems, but with the following principal differences:

- a. HPN utilizes Greenheck ERVs that have lower design heat recovery effectiveness and higher fan power than the HPS Swegon Gold ERVs
- b. HPN has trunk distribution ducts are located above the roof, outside the conditioned envelope, whereas HPS ductwork is completely within the conditioned space.
- c. HPN corridors are served by a dedicated corridor ventilation unit, whereas HPS has the corridors ventilated by the Swegon ERVs.
- d. HPN apartments have dedicated range hood exhaust, ducted to the exterior, whereas HPS has local kitchen exhaust via the ERV and recirculating range hoods.

The tentative scope of the NEEA study includes monitoring N phase in early 2021, and the S phase shortly after it is constructed in early 2022. The following summarizes the monitoring that will be performed to assess the energy and other performance differences between N and S phase ventilation systems:

- > Real power or amperage of ERVs
- Real power or amperage, supply air, return air, and outside air temperature of N phase corridor RTU.

- Cove heater amperage and range hood energy on a sample of dwelling units (10% sample of units recommended)
- ERV supply, return, exhaust and outside air temperatures on (2) ERVs to determine typical ERV effectiveness (8 points)
- ERV supply temperature after entering the conditioned building space, and exhaust temperature leaving conditioned space, to determine the impact of roof ductwork heat loss (4 points)
- CO2, temperature, and relative humidity in a sample of dwelling units (same units where cove heaters are metered)

In addition, operational differences should be monitored between the two phases, such as how often filters need to be replaced, to better understand the long-term operating costs of centralized ERV systems, particularly as they compare to in-unit ERVs used in other Exemplary Building projects. NEEA has provided verbal commitment to cover the costs for monitoring and data analysis, as well as some level of energy model calibration, at least for the heating/ventilation systems.

CO2 HPWH Plant

The proposed design utilizes Sanden CO2 HPs in a central plant, "swing tank" configuration. There are 10 total HPs, with 5 units manifolded to supply hot water to a single 500-gallon tank, two tanks total, piped in parallel. HPs and primary storage tanks are located in the basement parking garage, and hot water is piped without recirc to the 4th floor swing tank, where it is circulated to apartments on the top four residential floors of the S phase project. Figure 4 provides a schematic diagram of the system. The current design utilizes an older approach for staging the HPs on/off, whereby each HP has its own temperature thermistor inserted into a well on the storage tank. The Sanden HP supplier is now offering a local controller that replaces the individual thermistor control with one thermistor that is used to more reliably and intelligently stage HPs on/off. We strongly recommend the design team adopt this new controller, and to have the controller integrated into the planned building wide BMS so it can be monitored, including alarms pushed though the interface that facility managers will use to manage other systems. Use of the Sanden controller should reduce the number of BMS points that need to be installed by the control contractor, and likely reduce first cost and improve long-term efficiency. At the time of this report publication, DESC has requested change order to include the Sanden controller.



Figure 4. HPS HPWH Plant Diagram

The recommended points to monitor for a robust post-occupancy study include:

- > Ambient air temperature in garage and outside.
- > Temperature of entering municipal water supply.
- Hot water sub-metering metering for each apartment, which is already included in the design, as well as additional meters for laundry rooms and janitor sink to capture total demand. The next best option would be a make-up water sub-meter for the HW plant, located in the basement.
- Outlet and inlet temperature for each heat pump, or at minimum, the entering and leaving temperature of each of the two manifolds for the HPs.
- > Current or power meter for each HP to confirm its status and measure system COP.
- Storage tank temperature, both temperature sensor used for HP control, as well as 3-4 other vertical points to monitor stratification.
- Temperature of hot water leaving the plant in the basement, as well as the temperature entering the swing tank on L4.

Hobson Place South

Exemplary Building Pre-Construction Energy Study

- Temperature leaving swing tank, as well as current or power for swing tank electric heating element(s).
- Temperature of supply to building after thermostatic mixing valve, and temperature of recirc return, prior to <u>and</u> after mixing with cold water from building, as well as make-up cold water at L4.
- Temperature of hot water at the top of each supply riser, adjacent to thermostatic balancing valve on L7.

In addition to monitoring performance, alarm criteria should be developed to notify DESC if a HP is not working or hot water supply from the plant drops below the target setpoint temperature. The added cost for all these metering points is hard to define since much of this is already included in the BMS scope already defined and/or available through the recommended Sanden HP controller. Further effort is needed to define the added equipment cost.

Thermostats

The thermostat planned for the S phase is the King WR230-B, which includes a terminal that that a magnetic window switch will be wired to. When the window is opened, the heater setpoint will be automatically setback to 60°F. With input from O'Brien360, King has also developed a prototype of a new thermostat, Model K-802, with similar capabilities as well as the ability to network and centrally monitor the space temperature, setpoint, heater status, and window status. Figure 5 illustrates the concept. This thermostat would provide a great deal of apartment specific data that is hard to capture, such as:

- > Typical heating setpoints
- > Temperature (at the thermostat) during the different seasons
- > Heating energy consumption for all the units
- > How often windows are open, particularly in the heating season

To install the system, the K-802 is anticipated to cost approximately \$50-100 more per thermostat than the WRP, at least initially based on the volume needed for HPS. Additionally, low voltage data wiring among the units to the multiplexers and main gateway would need to be added, at an estimated cost of ~\$250-300/unit. At the time of this report publication, DESC has evaluated and chosen not to pursue this thermostat alternative.

Hobson Place South

Exemplary Building Pre-Construction Energy Study



Figure 5. King K-802 Thermostat

Water and Electric Sub-Metering

A robust, apartment water submetering system has been planned for the Hobson Place project. Every unit will have hot and cold water submeters installed. These meters will report wirelessly to a central, Obvius Aquisuite A-8810 data acquisition server. O'Brien360 has proposed to DESC to utilize the CopperTree Analytics Kaizen FDD software to trend data from the Aquisuite on near real-time basis (15minute intervals), and send alarms based on high water flow rate and/or daily consumption. This will allow DESC to intervene as soon as possible if a tenant uses a very large volume of water in a short-time period. Leak detection algorithms will also be evaluated.

As described in the HPWH monitoring recommendations, there are loads on the central hot water system that are not currently metered, primarily the laundry rooms and janitor sinks on L4-7. To add these meters to the current scope, the estimated cost is ~\$2,000, there would be no additional costs for software to monitor these points.

Additionally, an apartment electric sub-metering system is defined in the current scope since the project is master-metered. However, due to added cost, there is currently no plan to integrate the electric submeters into the Kaizen FDD platform that will be used for water metering. The estimated cost to implement the electric sub-metering trending and analytics is anticipated to be minimal. Having both electric and water sub metering would be very useful for calibrating the loads of the whole building energy model developed for this study.

Revision	Date	Originator	Description
01	7/12/2021	DR	First draft for SCL review. Models and results based on r56.
02	8/21/2020	DR	Second draft for SCL review. Models and results based on r62.
03	12/15/2020	DR	Final draft for DESC review. Models and results based on r66
04	2/19/2021	DR	Incorporate comments from JM, update results/LCCA to use
			final ERV cost estimate and also revise LCCA Alt 1 to include
			sales tax
05	6/18/2021	DR	Incorporate comments from PW. Remove L1 trash and
			mechanical rooms from the scope. Models and results based
			on r67.
06	7/12/2021	JP	Incorporate comments from PW. Remove shafts from the
			scope. Move recirculation pumping energy from modeled
			energy to non-modeled energy. Revise DHW table format.

V. Appendices

- Appendix A Floor Plan Area Diagrams
- Appendix B Heat Pump Hot Water Model
- Appendix C Incremental Cost Estimate Detail
- Appendix D eQUEST BEPS Output For Each Run



Appendix A - Floor Plan Area Diagrams

LEVEL 1 – FLOOR PLAN



LEVEL 2 & 3 – FLOOR PLAN



LEVEL 4~7 – FLOOR PLAN



Appendix B - Heat Pump Hot Water Model

The following page provides a snapshot of the hourly model developed for the central electric (resistance and/or heat pump) hot water plant. The complete spreadsheet can be provided upon request. The primary output of the model is monthly/annual hot water heating electricity and recirculation pump energy.



					1									Return to																	1	
</td <td></td> <td></td> <td></td> <td></td> <td></td> <td>Total Tot</td> <td>al Useful</td> <td></td> <td></td> <td>C</td> <td>irculation</td> <td>Swi</td> <td>ng</td> <td>Swing</td> <td>Swing</td> <td></td> <td></td> <td>H2O Temp</td> <td>Storage Storag</td> <td>e Storage Storage</td> <td>Storage</td> <td></td> <td>MU H2O to</td> <td>1</td> <td>Tank Cold</td> <td>Hot H2O</td> <td></td> <td>Hot H2O</td> <td></td> <td></td> <td></td> <td></td>						Total Tot	al Useful			C	irculation	Swi	ng	Swing	Swing			H2O Temp	Storage Storag	e Storage Storage	Storage		MU H2O to	1	Tank Cold	Hot H2O		Hot H2O				
N m N m N m N m N m N m N m N m N m N m				Condenser	MU H2O	Demand Dem	and DHW	Swing	Building	Return H2O Circulation	Pump	Circulation Tank I	- Heat Swing tank	Tank	Recirculate Tank Dra	w Prim, Tank MU H2O	Heat Trace	Through Main	Tank Cold Tank Co	old Tank Heat Tank Hea	t Tank Cold Targe	t Cold	Tank MU	H2O to HP	120 to HP H20 to HP	P Needed to	HP Flow	from HP	Heating	Defrost		
I I I I I I <	Month	Dav	Hour	Day Type Air Temp	Temp	Flow Volu	me Energy	Tank Temp S	upply Temp	Temp Heat Loss	Energy	Pump Gains Los	s Backup Heat	Volume	Volume Volume	Draw Volume Volume	Pipe Loss Energy	Riser	H20 Temp H20 Ter	mp Loss (Hot) Loss (Cole	 H20 Level H20 	Level HP On?	Volume	Volume	Volume Temp	Target	Capacity	Volume	Demand	Cycle On?	HP COP	HP Run Fraction HP Power
		,		• F	°F	dum da	al kBtu	°F	° F	° F Btu	kWh	Btu Bt	Rtu	gal	dal dal	dal dal	Btu Btu	° F	° F ° F	Rtu Rtu	%	6 0/1	gal	gal	∉al ° F	dal	gal	gal	kRtu	0/1		ratio kWh
	1	1	1	0 07.4	54.0	5pm 50	x 70 47.0	105.00	100.0	117.5 10.415	0.440	000 5	0.0	144.1	455.0	gui gui	057.05	100.5	140.0 54.0	011 1 01	70 0.000 F	0 0/1	gui	601	gui	gui	Bai	gui	RDtu	0/1		
	1	1	1	8 37.4	54.3	1.45 8	36.78 47.2	9 125.00	120.0	117.5 13,415	0.446	803.5 5		144.1	455.9 230.	9 86.8 -	357.35 -	139.5	140.0 54.3	641.1 Z1.	J 38% 5	J% U	86.8	-	- 0.0	-	-	-	-	1	-	
	1	1	2	8 35.6	54.3	1.68 10	00.72 54.8	8 125.33	120.0	117.5 13,415	0.446	803.5 5		124.9	475.1 225.0	6 100.7 0.0	357.35 -	139.4	139.9 54.3	569.4 24.	4 46% 5	0% 0	100.7	-	- 0.0	-	-	-	-	1	-	- 0%
	1	1	3	8 35.6	54.3	1.57 9	94.16 51.3	126.49	120.0	117.5 13,415	0.446	803.5 50	64.9 -	100.7	499.3 194.3	8 94.2 0.0	357.35 -	139.2	139.7 54.3	486.5 28.	3 56% 3	3% 1	0.0	94.2	97.9 54.3	272.1	192.0	192.0	136.5	1	3.1	100% 12.9
	1	1	4	8 33.8	54.3	1.16 6	i i i i i i i i i i i i i i i i i i i	7 127.19	120.0	117.5 13,415	0.446	803.5 5	- 1.9	105.0	495.0 174.	3 69.3 (0.0) 357.35 -	139.1	139.7 54.3	566.1 24.	4 47% 3	3% 1	0.0	69.3	85.1 54.3	154.4	192.0	154.4	109.8	1	3.1	80% 10.5
	1	1	5	8 33.8	54.3	1.30 7	78.05 42.5	3 126.36	120.0	117.5 13,415	0.446	803.5 50	- 63.6	115.1	484.9 193.	1 78.0 -	357.35 -	139.1	139.7 54.3	635.0 21.	0 38% 3	3% 1	0.0	78.0	4.3 54.3	82.4	192.0	82.4	58.6	1	3.1	43% 5.6
I I I I I I	1	1	6	8 33.8	54.3	1 19 7	71.22 38.8	126.06	120.0	117.5 13.415	0 446	803.5 5	- 30.6	126.7	473.3 197	9 71.2 -	357 35 -	139.0	139.6 54.3	637.9 20	8 38% 3	3% 0	71.2	-	- 0.0	-	-	-	-	1	-	
	1	1	3	0 25.6	54.2	1.14	20 E0 27.2	10 105.00	120.0	117.5 12.415	0.446	902 E EI	2.2.2	147.0	452.0 215	6 69.6	357.35	100.0	120.4 54.2	570.0 20.	C 4E0/ E	0	69.6		0.0	-				1		0%
I I V V V V V V V V V V V V V V V V V V V	1	1	1	0 35.0	54.5	1.14 6	50.59 57.5	120.32	120.0	117.5 13,415	0.440	603.5 5		147.0	455.0 215.0	0 08.0 -	557.55 -	130.0	159.4 54.5	3/9.2 23.	0 40% 0	J% U	00.0	-	- 0.0	-	-	-	-	1	-	0% -
1 1 1 1 1 1 1 1 1 1 1 <	1	1	8	8 35.6	54.3	1.21 7	2.84 39.6	9 124.40	120.0	117.5 13,415	0.446	803.5 54	- 14.0	173.0	427.0 245.	8 72.8 0.0	357.35 -	138.7	139.3 54.3	522.7 26.	3 51% 3	3% 1	0.0	72.8	119.2 54.3	205.8	192.0	192.0	136.6	1	3.1	100% 12.9
1 1 1 1 1 1 <	1	1	9	8 35.6	54.3	1.65 9	99.22 54.0	123.70	120.0	117.5 13,415	0.446	803.5 53	- 37.0	184.7	415.3 284.	0 99.2 -	357.35 -	139.0	139.4 54.3	620.0 21.	6 40% 3	3% 1	0.0	99.2	19.8 54.3	119.0	192.0	119.0	84.6	1	3.1	62% 8.0
1 1	1	1	10	8 35.6	54.3	1.74 10	04.29 56.8	3 124.64	120.0	117.5 13,415	0.446	803.5 54	- 16.4	144.4	455.6 248.	7 104.3 -	357.35 -	139.0	139.4 54.3	636.0 20.	8 38% 3	3% 1	0.0	104.3	1.0 54.3	105.3	192.0	105.3	74.9	1	3.1	55% 7.1
1 1 1 1 1 1 1 1 1 <	1	1	11	8 37.4	54.3	1.50 9	90.13 49.1	1 125.88	120.0	117.5 13.415	0.446	803.5 5	58.8 -	117.7	482.3 207.	9 90.1 -	357.35 -	138.9	139.4 54.3	636.7 20.	7 38% 3	3% 0	90.1	-	- 0.0	-	-	-	-	1	-	- 0%
N N N N N N N <	1	1	12	8 39.2	5/1.3	1 50 0	5 3 5 1 0	126.24	120.0	117.5 13./15	0.446	803.5 54	52.4	105.4	494.6 200	7 053	357 35	138.8	130.2 54.3	562.7 24	2 //7% 5	0	95.3		- 0.0	-		_		1		0%
	1	1	12	9 41.0	64.2	1.53	1 71 40.0	7 126.99	120.0	117.6 12.415	0.116	202.5 EI	0.0	04.4	E0E 6 196	1 01.7	267.26	129.6	120.1 54.2	494.9 29	2 2000	20/ 1	0.0	01.7	100.2 54.2	267.9	102.0	102.0	126.6	0	4.0	100% 0.0
1 1	1	1	13	8 41.0	54.5	1.55	49.9	120.88	120.0	117.5 13,415	0.440	803.3 5		34.4	545.0 180.	1 31.7 -	357.35	130.0	135.1 34.3	404.0 20.	0 10% 0	370 1	0.0	51.7	100.3 54.3	207.0	192.0	152.0	130.0	0	4.0	100/6 5.5
1 1 1 1 1 1 <	1	1	14	8 39.2	54.3	1.59 9	35.65 52.1	.2 127.25	120.0	117.5 13,415	0.446	803.5 5	(2.5 -	84.4	515.6 180.	1 95.6 -	357.35 -	138.9	139.3 54.3	567.2 24.	J 46% 3	3% 1	0.0	95.6	80.9 54.3	1/6.5	192.0	176.5	125.5	1	3.2	92% 11.5
1 1 1 1 1 1 <	1	1	15	8 37.4	54.3	1.57 9	94.16 51.3	1 127.92	120.0	117.5 13,415	0.446	803.5 5	- 19.2	74.0	526.0 168.	2 94.2 -	357.35 -	138.9	139.4 54.3	633.2 20.	8 38% 3	3% 1	0.0	94.2	4.1 54.3	98.3	192.0	98.3	69.9	1	3.1	51% 6.5
	1	1	16	8 33.8	54.3	1.77 10	06.10 57.8	1 128.53	120.0	117.5 13,415	0.446	803.5 5	- 35.3	55.6	544.4 161.	7 106.1 0.0	357.35 -	139.0	139.4 54.3	636.4 20.	7 38% 3	3% 0	106.1	-	- 0.0	-	-	-	-	1	-	- 0%
N N N N N N N N N N N <	1	1	17	8 33.8	54.3	1.99 11	19.22 64.9	6 129.84	120.0	117.5 13,415	0.446	803.5 59	- 98.4	28.0	572.0 147.3	2 119.2 -	357.35 -	138.9	139.2 54.3	549.5 24.	8 48% 5	0% 0	119.2	-	- 0.0	-	-	-	-	1	-	- 0%
1 1 1 1 1 1 <	1	1	18	8 33.8	54.3	2 11 12	6 78 69 0	131.89	120.0	117.5 13.415	0 446	803.5 6	- 189	0.8	599.2 127	6 126.8 -	357 35 -	138.7	139.0 54.3	452.3 29	5 59% 3	3% 1	0.0	126.8	65 3 54 3	340.9	192.0	192.0	136.5	1	3.1	100% 13.1
1 1 1 1 1 1 1 1 1 1 <	1	1	10	0 22.0	64.2	2.09 12	04.61 67.9	E 124.22	120.0	117.5 12.415	0.116	902 E 6	12.2	0.0	600.0 121	2 121.2 2.3	267.26	120.0	120.2 54.2	E06.5 26	0 52% 2	20/ 1	0.0	121.2	70.9 54.2	272.4	102.0	102.0	126.6	1	2.1	100% 12.1
1 1 2 3 5 5 5 5 5 5 5 <	1	1	19	8 33.8	54.5	2.08 12	07.8	134.32	120.0	117.5 13,415	0.440	803.3 04	+3.2 -	-	000.0 121.	2 121.2 3.3		135.0	135.3 34.3	500.5 20.	3 JJ/0 J	370 1	0.0	121.2	70.8 54.3	213.4	192.0	192.0	130.0	1	3.1	100% 13.1
1 1 1 1 1 1 <	1	1	20	8 33.8	54.3	1.77 10	06.05 57.7	9 135.84	120.0	117.5 13,415	0.446	803.5 6	- 08.4	-	600.0 104.	1 104.1 2.0	357.35 -	139.0	139.4 54.3	564.6 24.	1 46% 3	3% 1	0.0	104.1	84.9 54.3	189.0	192.0	189.0	134.4	1	3.1	98% 12.9
1 1	1	1	21	8 33.8	54.3	1.69 10	01.39 55.2	136.63	120.0	117.5 13,415	0.446	803.5 6	6.3 -	-	600.0 99.4	4 99.4 2.0	357.35 -	139.1	139.5 54.3	633.9 20.	8 38% 3	3% 1	0.0	99.4	4.3 54.3	103.7	192.0	103.7	73.7	1	3.1	54% 7.1
1 1 0 4 0 4 0 4 0 4 0 4 0 4 0 4 0 0 0 0 0 0 0 <	1	1	22	8 33.8	54.3	1.63 9	97.82 53.3	0 137.14	120.0	117.5 13,415	0.446	803.5 6	- 1.4	-	600.0 95.	9 95.9 1.9	357.35 -	139.0	139.5 54.3	637.1 20.	6 38% 3	3% 0	95.9	-	- 0.0	-	-	-	-	1	-	- 0%
1 1 1 1 1 1 <	1	1	23	8 33.8	54.3	1.76 10	05.74 57.6	137.45	120.0	117.5 13,415	0.446	803.5 6	- 4.5	-	600.0 101.	8 101.8 3.9	357.35 -	138.9	139.3 54.3	558.4 24.	4 47% 5	0%	101.8	-	- 0.0	-	-	-	-	1	-	- 0%
1 1 1 1 1 1 <	1	1	24	8 33.8	54.3	1.77 10	06.01 57.7	7 137.66	120.0	117.5 13.415	0.446	803.5 6	76.6 -	-	600.0 101.3	8 101.8 4.2	357.35 -	138.7	139.2 54.3	475.1 28.	4 57% 3	3% 1	0.0	101.8	90.3 54.3	289.7	192.0	192.0	136.6	1	3.1	100% 13.1
1 1 1 1 1 1	1	2	1	6 33.8	54.3	1.45 8	86.78 47.2	9 137.75	120.0	117.5 13.415	0 446	803.5 6	775 -	-	600.0 86	5 865 0.2	357 35 -	138.9	139.4 54.3	549.3 24	8 48% 3	3% 1	0.0	86.5	1023 543	188.8	192.0	188.8	134.3	1	3.1	98% 12.9
1 1	1	2	2	6 22.9	54.2	1.00 10	0.72 54.9	107.70	120.0	117.6 12.415	0.446	902 E 6	77.0		600.0 07	5 00.5 0.2	257.35	120.0	120.4 54.2	622.7 20	9 200/ 2	20/ 1	0.0	07.5	E 2 E 4 2	100.0	102.0	100.0	72.0	1	2.1	E20/ 7.0
1 1 1 1 1 1 <	1	2	2	0 33.0	54.5	1.00 10	JU.12 54.6	10 137.79	120.0	117.5 13,415	0.440	603.5 0		-	600.0 97.	5 97.5 5.3		159.0	159.4 54.5	632.7 20.	5 39% 3	570 1	0.0	97.5	5.2 54.5	102.0	192.0	102.0	15.0	1	3.1	53% 7.0
1 1 1 1 1 1 1 1 1 <	1	2	3	6 33.8	54.3	1.57 9	94.16 51.3	1 137.91	120.0	117.5 13,415	0.446	803.5 6		-	600.0 92.3	2 92.2 2.0	357.35 -	138.9	139.4 54.3	636.7 20.	6 38% 3	3% 0	92.2	-	- 0.0	-	-	-	-	1	-	- 0%
1 1 1 1 1 1 <	1	2	4	6 33.8	54.3	1.16 6	59.32 37.7	7 137.95	120.0	117.5 13,415	0.446	803.5 6	- 79.5	13.4	586.6 82.3	8 69.3 -	357.35 -	138.7	139.3 54.3	561.1 24.	2 47% 5	0% 0	69.3	-	- 0.0	-	-	-	-	1	-	- 0%
1 1 4 5 4 5 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 <	1	2	5	6 33.8	54.3	1.30 7	78.05 42.5	3 136.99	120.0	117.5 13,415	0.446	803.5 6	- 69.9	9.9	590.1 88.	0 78.0 -	357.35 -	138.6	139.1 54.3	504.2 26.	9 53% 3	3% 1	0.0	78.0	114.0 54.3	231.6	192.0	192.0	136.6	1	3.1	100% 13.1
	1	2	6	6 33.8	54.3	1.19 7	1.22 38.8	1 136.52	120.0	117.5 13,415	0.446	803.5 6	- 55.2	18.0	582.0 89.3	2 71.2 -	357.35 -	138.7	139.3 54.3	597.5 22.	5 43% 3	3% 1	0.0	71.2	45.3 54.3	116.6	192.0	116.6	82.9	1	3.1	61% 8.0
1 </td <td>1</td> <td>2</td> <td>7</td> <td>6 33.8</td> <td>54.3</td> <td>1.14 6</td> <td>8.59 37.3</td> <td>8 135.68</td> <td>120.0</td> <td>117.5 13.415</td> <td>0.446</td> <td>803.5 6</td> <td>56.8 -</td> <td>24.4</td> <td>575.6 93.0</td> <td>0 68.6 (0.0</td> <td>) 357.35 -</td> <td>138.7</td> <td>139.3 54.3</td> <td>634.3 20.</td> <td>7 38% 3</td> <td>3% 1</td> <td>0.0</td> <td>68.6</td> <td>2.3 54.3</td> <td>70.9</td> <td>192.0</td> <td>70.9</td> <td>50.4</td> <td>1</td> <td>3.1</td> <td>37% 4.8</td>	1	2	7	6 33.8	54.3	1.14 6	8.59 37.3	8 135.68	120.0	117.5 13.415	0.446	803.5 6	56.8 -	24.4	575.6 93.0	0 68.6 (0.0) 357.35 -	138.7	139.3 54.3	634.3 20.	7 38% 3	3% 1	0.0	68.6	2.3 54.3	70.9	192.0	70.9	50.4	1	3.1	37% 4.8
1 1 1 1 1 1 1 1 1 1 <	1	2	8	6 33.8	54.3	1.21 7	72.84 39.6	9 134.69	120.0	117.5 13.415	0 446	803.5 6	16.9 -	26.1	573.9 98	9 728 0.0	357 35 -	138.7	1393 543	635.8 20	5 38% 3	3% 0	72.8	-	- 0.0	-	-	-	-	1	-	
1 1 1 0 0 0 0 0 <	1	2	0	6 33.0	54.2	1.65	0.00 54.0	7 122.05	120.0	117.5 12.415	0.446	802.5 6	10.5	0.0	E01.0 107	4 00.0	257.35	100.7	120.1 54.2	576.0 23	4 450/ 5	0	00.0		0.0	-				1		0%
1 2 3 4 3 5 5 5 5 5 5 5 <	1	2	9	6 32.0	54.5	1.05 5	99.22 54.0	135.95	120.0	117.5 13,415	0.440	603.5 6.		0.2	591.6 107.4	4 99.2 -	557.55 -	136./	159.1 54.5	576.0 23.	4 40% 0	J% U	99.2	-	- 0.0	-	-	-	-	1	-	0% -
1 1 1 1 1 1 <	1	2	10	6 33.8	54.3	1.74 10	J4.29 56.8	i3 134.76	120.0	117.5 13,415	0.446	803.5 64	17.6 -	-	600.0 104.0	0 104.0 0.2	357.35 -	138.b	139.0 54.3	495.0 27.	3 54% 3	5% 1	0.0	104.0	88.0 54.3	267.5	192.0	192.0	136.6	1	3.1	100% 13.1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 </td <td>1</td> <td>2</td> <td>11</td> <td>6 35.6</td> <td>54.3</td> <td>1.50 9</td> <td>90.13 49.1</td> <td>.1 135.76</td> <td>120.0</td> <td>117.5 13,415</td> <td>0.446</td> <td>803.5 6</td> <td>57.6 -</td> <td>5.4</td> <td>594.6 95.</td> <td>6 90.1 -</td> <td>357.35 -</td> <td>138.8</td> <td>139.2 54.3</td> <td>567.5 23.</td> <td>8 46% 3</td> <td>3% 1</td> <td>0.0</td> <td>90.1</td> <td>79.9 54.3</td> <td>170.0</td> <td>192.0</td> <td>170.0</td> <td>120.9</td> <td>1</td> <td>3.1</td> <td>89% 11.4</td>	1	2	11	6 35.6	54.3	1.50 9	90.13 49.1	.1 135.76	120.0	117.5 13,415	0.446	803.5 6	57.6 -	5.4	594.6 95.	6 90.1 -	357.35 -	138.8	139.2 54.3	567.5 23.	8 46% 3	3% 1	0.0	90.1	79.9 54.3	170.0	192.0	170.0	120.9	1	3.1	89% 11.4
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 </td <td>1</td> <td>2</td> <td>12</td> <td>6 39.2</td> <td>54.3</td> <td>1.59 9</td> <td>95.33 51.9</td> <td>5 136.04</td> <td>120.0</td> <td>117.5 13,415</td> <td>0.446</td> <td>803.5 6</td> <td>- 50.4</td> <td>-</td> <td>600.0 95.3</td> <td>2 95.2 0.1</td> <td>357.35 -</td> <td>138.9</td> <td>139.3 54.3</td> <td>632.9 20.</td> <td>7 38% 3</td> <td>3% 1</td> <td>0.0</td> <td>95.2</td> <td>4.1 54.3</td> <td>99.3</td> <td>192.0</td> <td>99.3</td> <td>70.6</td> <td>1</td> <td>3.2</td> <td>52% 6.5</td>	1	2	12	6 39.2	54.3	1.59 9	95.33 51.9	5 136.04	120.0	117.5 13,415	0.446	803.5 6	- 50.4	-	600.0 95.3	2 95.2 0.1	357.35 -	138.9	139.3 54.3	632.9 20.	7 38% 3	3% 1	0.0	95.2	4.1 54.3	99.3	192.0	99.3	70.6	1	3.2	52% 6.5
1 2 N 5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	1	2	13	6 38.5	54.3	1.53 9	91.71 49.9	7 136.64	120.0	117.5 13,415	0.446	803.5 6	6.4	-	600.0 91.	6 91.6 0.1	357.35 -	138.8	139.3 54.2	636.0 20.	5 38% 3	3% 0	91.6	-	- 0.0	-	-	-	-	1	-	0% -
1 1 1 1 1 1 1 1 1 1 <	1	2	14	6 37.4	54.3	1.59	5.65 52.1	2 137.02	120.0	117.5 13.415	0.446	803.5 6	70.2 -	-	600.0 94.3	3 94.3 1.3	357.35 -	138.7	139.2 54.3	560.9 24	1 47% 5	0%	94.3	-	- 0.0	-	-	-	-	1	-	- 0%
1 2 1 7 8 9 1 9 1 9 9 9 9 9 9 9 9 9 <	1	2	15	6 37.4	54.3	1.57 0	04.16 51.3	1 137.27	120.0	117.5 13.415	0.446	803.5 6	72.7		600.0 92	0 020 13	357.35	138.6	139.0 54.3	/83.0 27	8 56% 3	1	0.0	92.9	00.2 54.3	269.6	192.0	102.0	136.6	1	3.1	100% 12.7
1 2 1 6 6 6 6 6 <	1	2	10	0 37.4	54.0	1.37 10	04.10 51.5	1 107.20	120.0	117.5 10,415	0.440	000.5 0	12.1		000.0 52.	0 100.0 0.0	057.05	100.0	100.0 54.0	405.5 21.	0 400 0	1	0.0	100.0	00.0 54.0	205.0	102.0	104.0	101.4	1	0.1	100% 12.7
1 2 0 6 0 0 0 0 0 <	1	2	16	6 37.4	54.5	1.77 10	00.10 57.8	1 157.39	120.0	117.5 13,415	0.440	803.5 6		-	600.0 102.	2 102.2 3.9		130.0	159.5 54.5	365.4 24.	J 40% 3	570 1	0.0	102.2	62.0 54.5	104.0	192.0	164.6	151.4	1	5.1	96% 12.2
1 2 3 4 1 5 1 5 6 1 5 5 5 5 5 <	1	2	17	6 37.4	54.3	1.99 11	19.22 64.9	6 137.60	120.0	117.5 13,415	0.446	803.5 6	- 76.0	-	600.0 112.	3 112.3 6.9	357.35 -	139.0	139.4 54.3	633.0 20.	7 38% 3	3% 1	0.0	112.3	4.2 54.3	116.5	192.0	116.5	82.8	1	3.1	61% 7.7
1 1 1 1 1 1 <	1	2	18	6 37.4	54.3	2.11 12	26.78 69.0	137.83	120.0	117.5 13,415	0.446	803.5 6	- 78.3	-	600.0 117.	9 117.9 8.9	357.35 -	139.0	139.4 54.2	636.4 20.	5 38% 3	3% 0	117.9	-	- 0.0	-	-	-	-	1	-	0% -
	1	2	19	6 37.4	54.3	2.08 12	24.51 67.8	5 138.01	120.0	117.5 13,415	0.446	803.5 6	- 30.1	-	600.0 115.	9 115.9 8.6	357.35 -	138.8	139.2 54.3	539.9 25.	2 49% 5	0% 0	115.9	-	- 0.0	-	-	-	-	1	-	0% -
1 7 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 9 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 8 7 8 8 7 8 8 7 8	1	2	20	6 35.6	54.3	1.77 10	06.05 57.7	9 138.05	120.0	117.5 13,415	0.446	803.5 6	- 30.5	-	600.0 101.	3 101.3 4.7	357.35 -	138.6	139.0 54.3	445.4 29.	7 60% 3	3% 1	0.0	101.3	90.7 54.3	323.5	192.0	192.0	136.6	1	3.1	100% 12.9
1 2 2 2 4 5 5 5 5 5	1	2	21	6 37.4	54.3	1.69 10	01.39 55.2	5 137.98	120.0	117.5 13.415	0.446	803.5 6	79.8 -	-	600.0 97.3	8 97.8 3.6	357.35 -	138.9	139.3 54.3	520.2 26.	2 52% 3	3% 1	0.0	97.8	94.3 54.3	233.8	192.0	192.0	136.6	1	3.1	100% 12.7
1 2 3 5 7 5 5 5 5 7 5 5 5 5 7 5 5 5 5 5	1	2	22	6 37.4	5/1.3	1.63	7.82 53.3	137.00	120.0	117.5 13./15	0.446	803.5 6	79.9	-	600.0 94	0 0/0 20	357 35	130.0	139.4 54.3	507.3 22	5 //3% 3	8% 1	0.0	01.0	46.5 54.3	1/15	102.0	141.5	100.6	1	3.1	74% 9.4
1 2 2 6 3 6 3 6 3 6 3 6 5 6 5 6 6 6 6 6	1	2	22	6 25.6	64.2	1.00 1	57.6	129.02	120.0	117.6 12.416	0.116	0 2 C 0 2	20.2		600.0 101	1 101.1 4.6	267.26	120.0	120.4 54.2	625.1 20	200/ C	20/ 1	0.0	101.1	2.4 64.2	102.5	102.0	102.5	72.6	1	2.1	E4% 6.0
1 2 A 5 4 5 4 5 4 5 4 5	1	2	23	0 33.0	54.5	1.70 10	55.74 57.0	12 138.03	120.0	117.5 13,415	0.440	803.3 0		-	000.0 101.	1 101.1 4.0	057.05	135.0	135.4 54.3	033.1 20.	5 0000 0	3/6 1	0.0	101.1	2.4 34.3	103.5	152.0	103.5	13.0	1	3.1	54% 0.5
1 3 1	1	۷	24	0 31.4	54.3	1.11 10	51.1	1 138.09	120.0	117.5 13,415	0.440	oU3.5 bi	- 5.00	-	0.000	J 101.3 4.7		133'0	109.4 54.2	030.8 20.	3070 3	3/0 U	101.3	-	- 0.0		-	-	-	1	-	U70 -
1 3 2 7 34 43 14 40 51 64 53 75 64 53 75 54 43 72 54 43 72 54 43 72 64 55 75 75 75 75 75 <	1	3	1	/ 35.6	54.3	1.45 8	so./8 47.2	138.12	120.0	117.5 13,415	U.446	803.5 6	51.2 -	-	600.0 86.	2 86.2 0.6	357.35 -	138.8	139.3 54.3	553.8 24.	p 48% 5	J% 0	86.2	-	- 0.0	-	-	-	-	1	-	0% -
1 3 5 7 1 3 5 7 7 7	1	3	2	7 37.4	54.3	1.68 10	00.72 54.8	8 138.03	120.0	117.5 13,415	0.446	803.5 6	- 30.3	-	600.0 97.3	2 97.2 3.5	357.35 -	138.7	139.1 54.3	483.3 27.	9 56% 3	3% 1	0.0	97.2	94.9 54.3	275.2	192.0	192.0	136.6	1	3.1	100% 12.7
1 3 4 7 7.0 9.00 1.00 1.00 9.00 4.0 9.00 9.00 9.00 <	1	3	3	7 37.4	54.3	1.57 9	94.16 51.3	1 137.97	120.0	117.5 13,415	0.446	803.5 6	- 79.7	-	600.0 92.	1 92.1 2.1	357.35 -	138.9	139.3 54.3	561.2 24.	2 47% 3	3% 1	0.0	92.1	88.0 54.3	180.1	192.0	180.1	128.1	1	3.1	94% 11.9
1 3 5 7 7.4 4.3 1.39 7.00 4.25 1.39 1.30	1	3	4	7 37.4	54.3	1.16 6	69.32 37.7	7 137.97	120.0	117.5 13,415	0.446	803.5 6	79.7 -	13.4	586.6 82.	7 69.3 -	357.35 -	138.8	139.4 54.3	633.1 20.	7 38% 3	3% 1	0.0	69.3	4.5 54.3	73.8	192.0	73.8	52.5	1	3.1	38% 4.9
1 3 6 7 58 543 119 712 381 136 126 143 542 136 512 136 512 136 512 136 512 136 513 136 136 513 136 136 136 513 513 136 136 136 136 513 513 136 513 513 513 <	1	3	5	7 37.4	54.3	1.30 7	78.05 42.5	3 137.03	120.0	117.5 13.415	0.446	803.5 6	70.3 -	9.7	590.3 87.3	8 78.0 -	357.35 -	138.8	139.4 54.2	636.3 20.	5 38% 3	3% 0	78.0	-	- 0.0		-	-	-	1	-	0% -
1 2 -	1	2	-	7 25.4	54.3	1 10 7	1 22 39.0	136.62	120.0	117.5 13.415	0.446	202.5	i6.2 -	17.6	582.5 00	8 71.2	357 35	138.6	139.2 64.2	572.2 20	6 45% 5	- 0	71.2		- 0.0		-			1		0%
1 1	1	2	7	7 33.0	54.5	1.15	1.22 30.0 29.50 27.2	10 105.02	120.0	117.5 13,415	0.446	003.5 0	7.6	24.0	502.5 00.	6 69.6	357.35	100.0	130.1 54.3	E12.0 26	4 520/ 2	1	0.0	69.6	102.4 54.2	210.5	102.0	102.0	126.6	1	2.1	100% 12.1
1 3 0 7 33 6 7 33 6 7 33 6 7 20 543 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.5 1.6 920 1.6 1.6 1.6 920 1.5 1.6 1.6 1.6 1.6	1	 	1	1 33.8	54.0	1.14 0	30.35 37.3	10170	120.0	117.5 10,415	0.440	000.0 0		24.0	570.0 92.	0 70.0	331.33 -	130.4	100.0 51	J1J.0 20.	- JZ/0 3	1 10	0.0	0.00	12.3.4 04.3	210.5	192.0	192.0	120.0	1	3.1	100/0 13.1
1 3 9 7 320 543 1.65 922 543 1.15 1.15 1.15 </td <td>1</td> <td>3</td> <td>8</td> <td>/ 33.8</td> <td>54.3</td> <td>1.21 /</td> <td>(2.84 39.6</td> <td>9 134.72</td> <td>120.0</td> <td>117.5 13,415</td> <td>0.446</td> <td>803.5 64</td> <td>17.2 -</td> <td>25.9</td> <td>574.1 98.3</td> <td>8 /2.8 -</td> <td>357.35 -</td> <td>138.7</td> <td>139.3 54.3</td> <td>614.8 21.</td> <td>b 40% 3</td> <td>5% 1</td> <td>0.0</td> <td>/2.8</td> <td>24.7 54.3</td> <td>97.6</td> <td>192.0</td> <td>97.6</td> <td>69.4</td> <td>1</td> <td>3.1</td> <td>51% 6.7</td>	1	3	8	/ 33.8	54.3	1.21 /	(2.84 39.6	9 134.72	120.0	117.5 13,415	0.446	803.5 64	17.2 -	25.9	574.1 98.3	8 /2.8 -	357.35 -	138.7	139.3 54.3	614.8 21.	b 40% 3	5% 1	0.0	/2.8	24.7 54.3	97.6	192.0	97.6	69.4	1	3.1	51% 6.7
1 3 10 7 302 5.1 10.4 10.4 10.4 0.4 0.4 0.4 0.4	1	3	9	7 32.0	54.3	1.65 9	99.22 54.0	133.98	120.0	117.5 13,415	0.446	803.5 63	- 39.8	8.0	592.0 107.	3 99.2 -	357.35 -	138.8	139.3 54.2	634.8 20.	6 38% 3	3% 1	0.0	99.2	1.3 54.3	100.5	192.0	100.5	71.4	1	3.0	52% 7.0
	1	3	10	7 30.2	54.3	1.74 10	04.29 56.8	3 134.83	120.0	117.5 13,415	0.446	803.5 64	48.3 -	-	600.0 104.	0 104.0 0.3	357.35 -	138.8	139.3 54.2	635.7 20.	5 38% 3	3% 0	104.0	-	- 0.0	-	-	-	-	1	-	- 0%
1 3 12 7 302 543 159 516 1341 0.04 803 661 - 600 951 953 556 513 710 1345 0.46 803 665 - 6000 917 913 543 150 140 953 516 134 140 955 521 1345 0.46 8035 6659 - 6000 917 913 543 556 21 910 910 910 910	1	3	11	7 30.2	54.3	1.50 9	90.13 49.1	1 135.89	120.0	117.5 13,415	0.446	803.5 6	58.9 -	4.8	595.2 94.	9 90.1 -	357.35 -	138.6	139.1 54.3	550.7 24.	6 48% 5	0% 0	90.1	-	- 0.0		-	-	-	1	-	0% -
1 3 13 1 1.1 1.1 1.1 t	1	3	12	7 30.2	54.3	1.59	95.33 51 9	5 136.14	120,0	117.5 13.415	0,446	803.5 6	61.4 -	-	600.0 95	1 95.1 0.2	357.35 -	138.5	139.0 54.3	477.1 28	1 56% 3	3% 1	0.0	95.1	96,9 54.3	279.4	192.0	192.0	136.6	1	3.0	100% 13.6
h b	1	2	10	7 20.2	54.2	1.52	1 71 40.0	126.60	120.0	117.5 12.415	211.0	200.0 E	55.0		600.0 01	7 017 00	357 35	100.0	139.2 54.3	556.0 24	3 47% 3	1	0.0	01 7	023 64.2	104.0	102.0	104.0	100.0	-	2.0	96% 12.0
1 3 1 7 9 9 9 9 1	1	3	13	1 30.2	54.0	1.00	49.9	100.03	120.0	117.5 10,415	0.440	000.5 6		-	000.0 91.	, <u>51./</u> U.U		130.0	100.0 51.0	550.9 Z4.	J 41/0 3	1	0.0	91.7	52.3 04.3	104.0	192.0	104.0	130.6	1	3.0	50/0 13.0
1 3 1.5 7 3.0 4.5 1.7 3.0 4.6 3.0 5.7 5.0 5.0 5.0 5.0 5.0 5	1	3	14	/ 30.2	54.3	1.59 5	52.1	.2 136.96	120.0	117.5 13,415	U.44b	803.5 6	- 0.80	-	000.0 94.·	4 94.4 1.2	. 357.35 -	138.9	139.3 54.3	032.4 20.	1 38% 3	570 I	0.0	94.4	4./ 54.3	99.1	192.0	99.1	/0.4	1	3.0	52% 7.0
1 3 16 7 28.4 54.3 17 106 57.1 13.45 0.46 80.5 67.4 10.1 10.1 10.1	1	3	15	7 30.2	54.3	1.57 9	94.16 51.3	137.28	120.0	117.5 13,415	0.446	803.5 6	- 2.8	-	600.0 92.	9 92.9 1.3	357.35 -	138.9	139.3 54.2	636.1 20.	5 38% 3	5% 0	92.9	-	- 0.0	-	-	-	-	1	-	0% -
1 3 17 7 28. 5.3 199 192 64.9 13.45 0.46 80.3 67.6 1.2 1.2 1.0 1.1 0.0 11.2 7.8 5.3 2.1 12.0 13.65 1.0 1.2 1.2 1.0 1.1 0.0 11.2 7.8 5.3 1.0 1	1	3	16	7 28.4	54.3	1.77 10	06.10 57.8	1 137.48	120.0	117.5 13,415	0.446	803.5 6	- 74.8	-	600.0 102.	1 102.1 4.0	357.35 -	138.8	139.2 54.3	560.0 24.	2 47% 5	0% 0	102.1	-	- 0.0	-	-	-	-	1	-	0% -
1 3 18 7 28.4 54.3 2.11 126.7 69.08 137.3 120.0 117.5 134.6 0.46 80.3< 67.3 - 60.0 118.0 138.3 54.3	1	3	17	7 28.4	54.3	1.99 11	19.22 64.9	6 137.64	120.0	117.5 13,415	0.446	803.5 6	76.4 -	-	600.0 112.	2 112.2 7.0	357.35 -	138.6	139.0 54.3	476.6 28.	2 57% 3	3% 1	0.0	112.2	79.8 54.3	297.5	192.0	192.0	136.6	1	2.9	100% 13.8
1 3 1 7 2.6 5.3 2.0 1.4.5 6.7.6 1.7.5 1.4.5 0.4.6 8.8.5 6.7.9 1.6.0 1.6.0 1.6.0 5.7.5 1.0.0 </td <td>1</td> <td>3</td> <td>18</td> <td>7 28.4</td> <td>54.3</td> <td>2.11 12</td> <td>26.78 69.0</td> <td>18 137.73</td> <td>120.0</td> <td>117.5 13,415</td> <td>0.446</td> <td>803.5 6</td> <td>- 17.3</td> <td>-</td> <td>600.0 118.</td> <td>0 118.0 8.7</td> <td>357.35 -</td> <td>138.9</td> <td>139.3 54.3</td> <td>542.6 25.</td> <td>0 49% 3</td> <td>3% 1</td> <td>0.0</td> <td>118.0</td> <td>74.0 54.3</td> <td>227.5</td> <td>192.0</td> <td>192.0</td> <td>136.6</td> <td>1</td> <td>2.9</td> <td>100% 13.8</td>	1	3	18	7 28.4	54.3	2.11 12	26.78 69.0	18 137.73	120.0	117.5 13,415	0.446	803.5 6	- 17.3	-	600.0 118.	0 118.0 8.7	357.35 -	138.9	139.3 54.3	542.6 25.	0 49% 3	3% 1	0.0	118.0	74.0 54.3	227.5	192.0	192.0	136.6	1	2.9	100% 13.8
1 3 1	1	3	19	7 26.6	54.3	2.08 13	4.51 67.8	137 91	120.0	117.5 13.415	0.446	803.5 6	79.1 -	-	600.0 116	0 116.0 8.6	357.35 -	139.0	139.4 5/ 3	603.3 22	1 42% 3	3% 1	0.0	116.0	39.3 54.3	155.3	192.0	155.2	110.4	1	2.8	81% 11 /
1 3 2.0 3.0 2.00 3.0 3.0 4.0 3.0 4.0 3.0 4.0 3.0 4.0 3.0 4.0 4.0 3.0 3.0<	1	3	20	7 26.6	54.3	1 77 10	16.05 57.7	138.06	120.0	117.5 13.415	0.446	803.5	30.6		600.0 101	3 101.3 4.7	357.35	139.0	139.4 64.2	635.4 20	6 38% 2	2% 1	0.0	101.2	2.0 54.2	103.2	102.0	102.2	73.4	-	2.0	54% 76
1 3 2.1 7 2.0 9.7.5 1.02 101.0 9.7.5 1.02 101.0 10.7.5 10.4.6 00.0 9.7.6 1.02 10.7 10.7.6 10.7.	4		20	7 20.0	54.5	1.00	1 20 57.7	5 100.00	120.0	117.5 10.415	0.440	000.0 0	-		600.0 101.	c 07.0 07.0	257.25	100.0	100.4 51.0	626.0	- JU/0 - JU/0	20/ 0	0.0	101.9	2.0 04.0	103.3	152.0	103.3	13.4	1	2.0	J+/0 /.0
1 3 22 7 26.6 54.3 1.3 97.2 53.0 18.1 120.0 11.7.5 13.45 0.4.6 93.2 13.1 120.0 17.5 13.45 0.4.6 93.2 13.45 0.4.6 93.6 13.45 0.4.6 93.6 14.1 10.0 17.5 13.45 0.4.6 93.6 94.8 13.6 15.67 13.8	1	3	21	/ 26.6	54.3	1.09 10	11.39 55.2	.5 138.11	120.0	117.5 13,415	U.44b	803.5 6	- 1.1	-	6UU.U 97.I	o 97.6 3.8	357.35 -	138'0	159.4 54.2	030.8 20.	5 38% 3	570 U	97.0	-	- 0.0	-	-	-	-	1	-	U% -
1 3 23 7 26.6 54.3 1.76 105.74 57.62 138.06 120.0 117.5 13.415 0.446 803.5 680.6 - - 600.0 101.1 101.1 47.0 57.35 - 138.7 139.1 54.3 479.2 28.0 56% 38% 1 0.0 101.1 91.0 54.3 192.0 <th< td=""><td>1</td><td>3</td><td>22</td><td>7 26.6</td><td>54.3</td><td>1.63 9</td><td>97.82 53.3</td><td>IU 138.11</td><td>120.0</td><td>117.5 13,415</td><td>0.446</td><td>803.5 6</td><td>- 1.1</td><td>-</td><td>600.0 94.</td><td>8 94.8 3.0</td><td>357.35 -</td><td>138.8</td><td>139.3 54.3</td><td>556.7 24.</td><td>3 47% 5</td><td>J% 0</td><td>94.8</td><td>-</td><td>- 0.0</td><td></td><td>-</td><td>-</td><td>-</td><td>1</td><td>-</td><td>0% -</td></th<>	1	3	22	7 26.6	54.3	1.63 9	97.82 53.3	IU 138.11	120.0	117.5 13,415	0.446	803.5 6	- 1.1	-	600.0 94.	8 94.8 3.0	357.35 -	138.8	139.3 54.3	556.7 24.	3 47% 5	J% 0	94.8	-	- 0.0		-	-	-	1	-	0% -
1 3 24 7 26. 54.3 1.77 106.01 57.77 138.00 120.0 117.5 13.415 0.446 803.5 68.0 600.0 101.4 101.4 4.6 357.35 - 138.9 139.3 54.3 55.0 24.5 48% 38% 1 0.0 101.4 90.7 54.3 197.8 192.0 192	1	3	23	7 26.6	54.3	1.76 10	05.74 57.6	138.06	120.0	117.5 13,415	0.446	803.5 6	- 30.6	-	600.0 101.	1 101.1 4.7	357.35 -	138.7	139.1 54.3	479.2 28.	0 56% 3	3% 1	0.0	101.1	91.0 54.3	283.8	192.0	192.0	136.6	1	2.8	100% 14.1
	1	3	24	7 26.6	54.3	1.77 10	06.01 57.7	7 138.00	120.0	117.5 13,415	0.446	803.5 6	- 30.0	-	600.0 101.	4 101.4 4.6	357.35 -	138.9	139.3 54.3	554.0 24.	5 48% 3	3% 1	0.0	101.4	90.7 54.3	197.8	192.0	192.0	136.6	1	2.8	100% 14.1

		RESULTS		
		Heat to Supply	408,701	kBtu
nden		Heat Loss	131,998	kBtu
122	°F	Heat Pump Output	533,662	kBtu
113	°F	Heat Pump Input	37,242	kWh
38%	-	Heat Pump COP		
50%	-	Heat Pump Run Hours	3,906	FLH
140	°F	Backup Heater Output	-	kBtu
4000	W	Backup Heater Input	-	kWh
10		Swing T Heater Output	-	kBtu
	-	Swing T Heater Input	-	kWh
		System Output	533,662	kBtu
40.0	°F	System Input	37,242	kWh
-	mins/hr	System COP		(incl. HPs and back-up, but excl other)
20%				
127,070	kBtu/yr	Pump Energy	3,907	kWh
37,242	kWh/yr	Fan Power	-	kWh
	-	Total Electric Energy	41,149	kWh
		Total System COP		(incl. pumps, fans, etc)
				-
		Heat Pump		

Appendix C - Laundry Energy Calculations

In the laundry energy calculations, 1.5 washer & dryer cycles/apartment/week are assumed for both the proposed and baseline design, based on DESC laundry vendor data obtained for a previous project. Energy consumption and hot water consumption for the proposed and baseline design is based on ACEEE studies.

	Baseline	Proposed
Total Dwelling Units	9	2
Total Number of Occupants	9	2
Laundry Cycles (cycle/unit/week)	1	.5
Clothes Washer Hot Water Consumption (gallon/cycle)	10.3	2.7
Clothes Washer Energy Consumption (kWh/cycle)	0.15	0.16
Clothes Dryer Energy Consumption (kWh/cycle)	4	3
Total Hot Water Consumption (gallon/year)	74,116	19,428
Total Laundry Energy Consumption (kWh/year)	29,862	22,738

Appendix D - Incremental Cost Estimate Detail

Hobson Place - S SCL Energy Study Cost Estimating Summary

Date 7/12/2021

ECM ID	Proposed Case	Baseline Case	Walsh's Cost Estimating Approach Updated 3/19/20	Incremental First Cost Est. (\$)	Energy Savings (kwh/year)	Energy Cost Savings (\$/year)	Simple Payback (years)	Cost/Unit	Cost/SF	Incremental Maintenance Cost Est. (\$/year	Maintenance Cost Notes
	2x8 wood walls w/ R-30 blow-in batt, as designed	2x6 wood walls w/ R-21 blow-in batt	WCC: Per Magellan Insulation. Value of R-30 as compared to R-21 OB360: This is included in baseline to achieve C406.8	-	-	-		\$ -	\$ -	\$ -	No additional maintenace costs compared to baseline anticpated
A1.0	Wood joist roof with rigid insulation above deck, as designed (R-50 overall average)	Same roof structure with code-miniumum (R-38 overall average) rigid insulation above deck	WCC: Per Axiom D7. Value of increase from R-38 average to R-50 average. OB360: This is included in baseline to achieve C406.8	-	-	-		\$-	\$ -	\$ -	-
	Triple-pane vinyl windows, as designed	Double-pane vinyl windows, U-0.24	WCC: Per VPI Windows. Pricing to go from 0.24 to 0.18, per Budget Control log 8-29-20 and DD phase estimate.	52,750	15,039	1,504	35	\$ 573	\$ 1.1	3\$-	-
A2.0	Passive House air leakage target (0.08 cfm/ft2 at 75 Pascals)	Building envelope air leakage = 0.25 cfm/ft2 at 75 Pascals*	WCC: Used WCC Passive House Sealant Upgrades, per analysis provided to owner 10-4-19.	80,783	2,386	239	339	\$ 878	\$ 1.7	4 \$ -	No additional maintenace costs compared to baseline anticpated
E.1.0	All LED lighting fixtures, proposed design lighting power and controls	All LED lighting fixtures, 25% lower lighting power* than Table C405.4.2(2) and controls as required by code.	OB360: WCC indicates the cost for achieving the reduce lighting power targets in affordable housing projects is negligible.	-	4,152	415	-	\$-	\$-	\$-	No additional maintenace costs anticpated
E2.0	Energy Star refrigerators	Non-Energy Star refrigerators	OB360: At this given size, GE does not offer a non-Energy Star refrigerator. Whirlpool model WRT112CZJ has similar specifications and is not Energy Star, and the incremental cost in MSRP is \$430. A comparable Energy Star Fridgedaire model FFET1222 has an incremental MSRP cost of \$250 over the Whirlpool, so this incremental cost has been used assuming the cost for the GE refrigerator can be negotiated down with vendors.	6,900	1,317	132	52	\$ 75	\$ 0.1	5\$-	No additional maintenace costs anticpated
E3.0	Energy Star commercial washers in common laundry rooms	Non-Energy Star commercial washers in common laundry rooms	OB360: DESC leases laundry equipment from an outside vendor, and it is our understanding non-Energy Star commercial laundry appliances are no longer available.	-	15,005	1,500	-	\$-	\$-	\$ -	No additional maintenace costs compared to baseline anticpated
M1.0	Passive House ventilation system, as designed. - (3) Swegon rooftop energy recovery ventilators serving dwelling units and corridors. MERV 13 filters - Trunk ducting moved to inside the conditioned space, individual supply/exhaust duct drops to each unit. - Supply register in living area, exhaust register in bathroom and kitchen (grease filter behind kitchen grille) - Recirculating range hoods with carbon filter.	Code-minimum house/corridor ventilation: - AirKing AK-100D (or similar) two speed exhaust fan in each dwelling unit with two trickle vents in window. Venting of exhaust horizontally to exterior (same diameter as proposed exhaust ducts) - (2) Greenheck rooftop air handlers w/ electric heat for corridors. Same corridor supply/return flow rate as proposed, MERV 13 filters. - Kitchen exhaust hood vented horizontally to exterior (no carbon filter)	WCC: Used WCC costs for horizontal ductwork to in-unit bath fan and range hood fans at recent project. See supporting calculations below.	577,879	118,545	11,855	49	\$ 6,281	\$ 12.4	2 \$ 4,41	See Horiz. Ductwork Analysis + \$30/unit/year for recirculating hood filter
M2.0	Apartment heating system, as designed: - King thermostat for electric cove heaters that is wired to window switch that automatically sets back thermostat set point when window is open.	Line-voltage thermostat for electric cove heaters, no window switch.	WCC: \$1600 for the switches (VPI). Assume \$100/unit for low volt wiring, and \$50/unit for upgraded t-stats.	12,200	14,623	1,462	8	\$ 133	\$ 0.2	6	No additional maintenace costs compared to baseline anticpated
P1.0	Low-flow plumbing fixtures, as specified	Code-maximum flow plumbing fixtures	OB360: WCC indicates the cost for low-flow fixtures used in most affordable housing is negligible.	-	36,680	3,668	-	\$-	\$-	\$ -	No additional maintenace costs compared to baseline anticpated
P2.0	Current proposed DHW/DCW plumbing design: - One riser serving two apartments where it was possible. - Additional pipe insulation, as described by Add Alt in Spec 220700 3.5.A.1	"Typical" residential HW/CW plumbing design: - Same HW/CW distribution design <u>except</u> one HW/CW riser serving every stack of apartments. - Code minimum pipe insulation on HW supply and recirc.	WCC: Per Sunrise Plumbing: ROM for (7) additional stacks (\$24,500), plus cost premium for Revised DHW Routing and Increased Insulation Thickness for DHW and DCW system (\$55,000).	30,500	14,120	1,412	22	\$ 332	\$ 0.6	6\$-	No additional maintenace costs compared to baseline anticpated
P3.0	DHW heating plant, as designed: - (10) Sanden CO2 heat pumps with 2 – 500 gal storage tanks w/ R-16 insulation - Electric resistance back-up and temperature maintenance tank water heaters.	Electric resistance water heater plant with 2 – 500 gal storage tanks w/ code-minimum (R-12.5) insulation. Assume total electric water heater capacity is the same as the total peak) output of Sanden HPs (45 kW).	WCC: Amount for hypothetical hot water plant with electric water heaters at same capacity as existing design (Sunrise Plumbing), plus \$5000 electrical to wire, minus cost of Sanden Heat Pumps (\$50,000, per EAI).	73,000	160,924	16,092	5	\$ 793	\$ 1.5	7 \$ 1,000	Annual maintenance checks and fin cleaning
PV	Proposed PV system, as designed, 40.0 kW	C411.1 required PV system, 4.0 kW	Per NWWS. Cost of code-minimum 4kW system, \$30000. Per WCC, proposed PV system is \$106,247, including hoisting.	76,247	36,000	3,600	21	\$ 829	\$ 1.6	4 \$ -	No additional maintenace costs anticpated
L			r Totals (Not Incl PV) Total (Incl PV)	\$ 834,011 \$ 910,258	\$ 382,791 \$ 418,791	\$ 38,279 \$ 41,879	<u> </u>		!	\$ 5,41 \$ 5,41	, ,

Units

\$/kWh

0.10

	Area (ft2)
92	46,532

Appendix E - eQUEST Output Reports For Each Run

The eQUEST BEPS and BEPU reports are provided for each simulation run except P1.0 and P2.0, which were simulated using a separate model of the central hot water plant. As such, DHW energy is not reported in any of the reports. See Appendix B for model of baseline/proposed DHW energy use.

Baseline

2033_MDL00								DOE-	2.2-48z	6/04/20	10:	16:24 BD	LRUN 1
REPORT- BEF	PS Building	Energy Pe	erformance	•					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RESI ELECTE MBTU	RICITY 56.1	0.0	302.3	478.0	0.0	0.0	0.0	124.5	0.0	0.0	0.0	0.0	961.0
HOUS ELECTH MBTU	RICITY 133.8	0.0	30.8	106.8	3.7	0.0	0.0	35.4	0.0	0.0	0.0	0.0	310.5
EM1 ELECTF MBTU	RICITY 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FM1 NATURA MBTU	AL-GAS 0.0 	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
MBTU	189.9	0.0	333.1	584.8	3.7	0.0	0.0	159.9	0.0	0.0	0.0	0.0	1271.5

TOTAL SITE ENERGY	1271.46 MBTU	30.3 KBTU/SQFT-YR GROSS-AREA	30.3 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY	1271.46 MBTU	30.3 KBTU/SQFT-YR GROSS-AREA	30.3 KBTU/SQFT-YR NET-AREA
PERCENT OF HOURS ANY	SYSTEM ZONE OUTSI	DE OF THROTTLING RANGE = 0.11	

PERCENT OF HOORS AND	SISTEM ZONE COISIDE OF THROTTEING RANGE	_	0.11
PERCENT OF HOURS ANY	PLANT LOAD NOT SATISFIED	=	0.00
HOURS ANY ZONE ABOVE	COOLING THROTTLING RANGE	=	6
HOURS ANY ZONE BELOW	HEATING THROTTLING RANGE	=	4

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

2033	_MDL00								DOE-	2.2-48z	6/04/20	21 10:	16:24 BD	LRUN 1
REPO	DRT- BEPU H	Building	Utility H	Performanc	e					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RESI	ELECTRIC: KWH	ITY 16442.	0.	88565.	140062.	0.	0.	0.	36493.	0.	0.	0.	0.	281562.
HOUS	ELECTRIC: KWH	ITY 39208.	0.	9032.	31283.	1087.	0.	0.	10365.	0.	0.	0.	0.	90975.
EM1	ELECTRIC: KWH	ITY 0.	0.	Ο.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
FM1	NATURAL-(THERM	GAS 0.	0.	Ο.	0.	Ο.	0.	0.	0.	0.	0.	Ο.	0.	0.

TOTAL ELECTRICITY 372537. KWH 8.867 KWH /SQFT-YR GROSS-AREA 8.867 KWH /SQFT-YR NET-AREA PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.11 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.00 HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE = 6

	0.00	
HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE =	6	
HOURS ANY ZONE BELOW HEATING THROTTLING RANGE =	4	

A1.0 - Triple-pane Windows

2033_MDL00						DOE-	2.2-48z	6/04/20	21 10:	17:05 BD	LRUN 3		
REPORT- BEPS	Building H	Energy Pe	rformance						WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RESI ELECTRI MBTU	CITY 56.1	0.0	302.3	436.6	0.0	0.0	0.0	124.1	0.0	0.0	0.0	0.0	919.1
HOUS ELECTRI MBTU	ICITY 133.8	0.0	30.8	96.7	3.7	0.0	0.0	35.4	0.0	0.0	0.0	0.0	300.4
EM1 ELECTRI MBTU	CITY 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FM1 NATURAL MBTU	L-GAS 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
MBTU	189.9	0.0	333.1	533.3	3.7	0.0	0.0	159.5	0.0	0.0	0.0	0.0	1219.5
	TOT	AL SITE E	NERGY ENERGY	1219.52 1219.52	MBTU MBTU	29.0 KBT 29.0 KBT	U/SQFT-YR U/SQFT-YR	GROSS-AR GROSS-AR	EA 29 EA 29	0.0 KBTU/S	QFT-YR NE	T-AREA T-AREA	

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE	=	0.23
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED	=	0.00
HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE	=	8
HOURS ANY ZONE BELOW HEATING THROTTLING RANGE	=	12

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

2033_MDL00						DOE-2.2-48z 6/04/2021 10:17:05 BDL RUN							
REPORT- BEPU	Building	Utility P	erformand	æ					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RESI ELECTRIC KWH	ITY 16442.	0.	88565.	127929.	0.	0.	0.	36365.	0.	0.	0.	0.	269301.
HOUS ELECTRIC KWH	:ITY 39208.	0.	9032.	28327.	1087.	0.	0.	10365.	Ο.	Ο.	0.	0.	88020.
EM1 ELECTRIC KWH	:ITY 0.	0.	0.	0.	0.	0.	0.	0.	Ο.	Ο.	0.	0.	0.
FM1 NATURAL- THERM	GAS 0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.

TOTAL ELECTRICITY 357321. KWH 8.505 KWH /SQFT-YR GROSS-AREA 8.505 KWH /SQFT-YR NET-AREA

PERCENT OF HOURS ANY	SYSTEM ZONE OUTSIDE OF THROTTLING RANGE	=	0.23
PERCENT OF HOURS ANY	PLANT LOAD NOT SATISFIED	=	0.00
HOURS ANY ZONE ABOVE	COOLING THROTTLING RANGE	=	8
HOURS ANY ZONE BELOW	HEATING THROTTLING RANGE	=	12

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

7/12/2021

A2.0 – Reduced Air Leakage

203	3_MDL00								DOE-	2.2-48z	6/04/20	121 10:	17:38 BD	LRUN 4
REPO	DRT- BEPS	Building H	lnergy Pe	rformance	•					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RES	I ELECTRIC MBTU	ITY 56.1	0.0	302.3	469.7	0.0	0.0	0.0	124.5	0.0	0.0	0.0	0.0	952.6
HOUS	S ELECTRIC MBTU	ITY 133.8	0.0	30.8	106.9	3.7	0.0	0.0	35.4	0.0	0.0	0.0	0.0	310.6
EM1	ELECTRIC MBTU	ITY 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FM1	NATURAL- MBTU	GAS 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	MBTU	189.9	0.0	333.1	576.6	3.7	0.0	0.0	159.8	0.0	0.0	0.0	0.0	1263.2
TOTAL SITE ENERGY1263.22 MBTU30.1 KBTU/SQFT-YR GROSS-AREA30.1 KBTU/SQFT-YR NET-AREATOTAL SOURCE ENERGY1263.22 MBTU30.1 KBTU/SQFT-YR GROSS-AREA30.1 KBTU/SQFT-YR NET-AREAPERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE =0.21PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED=0.00HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE=6HOURS ANY ZONE BELOW HEATING THROTTLING RANGE=12NOTE:ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.														
203	3_MDL00								DOE-	2.2-48z	6/04/20	21 10:	17:38 BD	LRUN 4
REPO	ORT- BEPU	Building (Jtility P	erformanc	æ					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RES	I ELECTRIC KWH	ITY 16442.	0.	88565.	137630.	0.	0.	0.	36467.	0.	0.	0.	0.	279105.
HOUS	S ELECTRIC KWH	ITY 39208.	0.	9032.	31325.	1087.	0.	0.	10365.	0.	0.	0.	0.	91018.
EM1	ELECTRIC KWH	ITY 0.	0.	0.	Ο.	Ο.	0.	0.	0.	Ο.	Ο.	0.	0.	0.
FM1	NATURAL- THERM	GAS 0.	Ο.	0.	0.	0.	0.	0.	0.	0.	0.	Ο.	Ο.	Ο.
	то	TAL ELECTI	RICITY	370122.	KWH	8.810	KWH /	SQFT-YR G	ROSS-AREA	8.810	KWH	/SQFT-YR 1	NET-AREA	

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROT	TLING RANGE = 0.21	
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED	= 0.00	
HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE	= 6	
HOURS ANY ZONE BELOW HEATING THROTTLING RANGE	= 12	

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

7/12/2021

E1.0 – Reduced Interior Lighting Power

203	3_MDL00								DOE-	2.2-48z	6/04/20	021 10:	18:09 BD	LRUN 5
REP	ORT- BEI	PS Buildin	g Energy P	erformanc	e					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
		LIGHT	TASK S LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RES	I ELECTI	RICITY												
	MBTU	56.	1 0.0	302.3	480.5	0.0	0.0	0.0	124.6	0.0	0.0	0.0	0.0	963.5
HOU	S ELECTI MBTU	RICITY 83.	3 0.0	30.8	140.8	3.7	0.0	0.0	35.4	0.0	0.0	0.0	0.0	293.9
EM1	ELECTI MBTU	RICITY O.	0 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FM1	NATURA MBTU	AL-GAS 0.	0 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	MBTU	139.	4 0.0	333.1	621.3	3.7	0.0	0.0	159.9	0.0	0.0	0.0	0.0	1257.4
	TOTAL SITE ENERGY1257.37 METU29.9 KETU/SQFT-YR GROSS-AREA29.9 KETU/SQFT-YR NET-AREATOTAL SOURCE ENERGY1257.37 METU29.9 KETU/SQFT-YR GROSS-AREA29.9 KETU/SQFT-YR NET-AREAPERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE =0.08PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED =0.00HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE =5HOURS ANY ZONE BELOW HEATING THROTTLING RANGE =2NOTE:ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.													
203	3 MDL00								DOE-	2.2-48z	6/04/20	21 10:	18:09 BD	LRUN 5
REP	- ORT- BEI	PU Buildin	g Utility	Performan	ce					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
		LIGHT	TASK S LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RES	I ELECTI KWH	RICITY 16442	. 0.	88565.	140797.	0.	0.	0.	36501.	0.	0.	0.	0.	282304.
HOU	S ELECTI KWH	RICITY 24393	. 0.	9032.	41240.	1077.	Ο.	0.	10364.	0.	0.	0.	0.	86106.
EM1	ELECTI KWH	RICITY O	. 0.	0.	0.	0.	Ο.	0.	Ο.	0.	0.	0.	0.	0.
FM1	NATURA THERM	AL-GAS O	. 0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	٥.
		TOTAL ELE PERCENT O PERCENT O	CTRICITY F HOURS AN F HOURS AN	368410. Y SYSTEM S Y PLANT L	KWH ZONE OUTSI DAD NOT SA	8.769 DE OF THF TISFIED	KWH /	SQFT-YR G ANGE = 0 = 0	ROSS-AREA	8.765	KWH	/SQFT-YR	NET-AREA	

 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED
 =
 0.00

 HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE
 =
 5

 HOURS ANY ZONE BELOW HEATING THROTTLING RANGE
 =
 2

E2.0 – Energy Star Refrigerators

2033_MDL00						DOE-	2.2-48z	6/04/20	21 10:	18:36 BD	LRUN 6		
REPORT- BEPS	Building I	Energy Pe	rformance	•					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RESI ELECTRI MBTU	CITY 56.1	0.0	290.6	485.0	0.0	0.0	0.0	124.6	0.0	0.0	0.0	0.0	956.3
HOUS ELECTRI MBTU	CITY 133.8	0.0	30.8	106.8	3.7	0.0	0.0	35.4	0.0	0.0	0.0	0.0	310.6
EM1 ELECTRI MBTU	CITY 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FM1 NATURAL MBTU	-GAS 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
MBTU	189.9	0.0	321.5	591.8	3.7	0.0	0.0	160.0	0.0	0.0	0.0	0.0	1266.9
	TOTA	AL SITE E AL SOURCE	NERGY ENERGY	1266.91 1266.91	MBTU MBTU	30.2 KBT 30.2 KBT	U/SQFT-YR U/SQFT-YR	GROSS-AR GROSS-AR	EA 30 EA 30	0.2 KBTU/S	QFT-YR NE	T-AREA T-AREA	

 PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE
 0.11

 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED
 =
 0.00

 HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE
 =
 6

 HOURS ANY ZONE BELOW HEATING THROTTLING RANGE
 =
 4

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

DOE-2.2-48z 6/04/2021 10:18:36 BDL RUN 6

REP	EPORT- BEPU Building Utility Performance WEATHER FILE- SEATTLE BOEING FI WA													
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RES	I ELECTRIC KWH	16442.	Ο.	85156.	142093.	0.	0.	Ο.	36514.	0.	Ο.	0.	٥.	280205.
HOU	S ELECTRIC KWH	:ITY 39208.	0.	9032.	31307.	1087.	0.	Ο.	10365.	Ο.	Ο.	Ο.	Ο.	90999.
EM1	ELECTRIC KWH	СІТҮ 0.	Ο.	0.	Ο.	0.	0.	Ο.	Ο.	Ο.	Ο.	Ο.	Ο.	٥.
FM1	NATURAL- THERM	-GAS 0.	Ο.	0.	Ο.	0.	0.	Ο.	0.	Ο.	Ο.	٥.	Ο.	0.

TOTAL ELECTRICITY 371204. KWH 8.836 KWH /SQFT-YR GROSS-AREA 8.836 KWH /SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE	=	0.11
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED	=	0.00
HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE	=	6
HOURS ANY ZONE BELOW HEATING THROTTLING RANGE	=	4

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

2033_MDL00

M1.0 – Energy Recovery Ventilation (ERV) System

2033_MDL00	2033_MDL00 DOE-2.2-48z 6/04/2021 10:52:20 BDL RUN 10													
REPORT- BEPS	Building I	Energy Pe	rformance						WE	ATHER FIL	E- SEATTL	E BOEING	FI WA	
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL	
RESI ELECTRI(MBTU	CITY 56.1	0.0	302.3	163.4	0.0	0.0	16.1	155.3	0.0	0.0	0.0	0.0	693.2	
HOUS ELECTRI MBTU	CITY 133.8	0.0	30.8	0.5	3.2	0.0	0.0	0.6	0.0	0.0	0.0	0.0	168.9	
EM1 ELECTRI(MBTU	CITY 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
FM1 NATURAL MBTU	-GAS 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
MBTU	189.9	0.0	333.1	163.9	3.2	0.0	16.1	155.9	0.0	0.0	0.0	0.0	862.1	
	TOT: TOT:	AL SITE E AL SOURCE	NERGY	862.10 862.10	MBTU MBTU	20.5 KBT 20.5 KBT	U/SQFT-YR U/SQFT-YR	GROSS-AR GROSS-AR	EA 20 EA 20	.5 KBTU/S .5 KBTU/S	QFT-YR NE QFT-YR NE	T-AREA T-AREA		

PERCENT	OF	HOUR	RS ANY	SYSTEM	ZONE	OUTSIDE	OF	THROTTLING	RANGE	=	1.59
PERCENT	OF	HOUR	RS ANY	PLANT	LOAD 1	NOT SATI	SFIE	D		=	0.00
HOURS A	NY	ZONE	ABOVE	COOLIN	G THR	DTTLING	RANC	E		=	6
HOURS A	NY	ZONE	BELOW	HEATIN	G THR	DTTLING	RANC	E		=	133

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

203	3_MDL00								DOE-	2.2-48z	6/04/20	21 10:	52:20 BD	L RUN 10
REF	ORT- BEPU	Building	Utility F	Performanc	же					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RES	I ELECTRIC KWH	ITY 16442.	0.	88565.	47889.	0.	0.	4715.	45498.	0.	0.	0.	0.	203110.
HOU	IS ELECTRIC KWH	:ITY 39208.	Ο.	9032.	146.	926.	0.	Ο.	172.	Ο.	Ο.	0.	0.	49484.
EM1	ELECTRIC KWH	. О.	Ο.	0.	Ο.	0.	0.	Ο.	0.	Ο.	Ο.	0.	0.	0.
FM1	NATURAL- THERM	GAS 0.	Ο.	0.	Ο.	0.	0.	Ο.	0.	Ο.	Ο.	0.	0.	0.

TOTAL ELECTRICITY 252594. KWH 6.012 KWH /SQFT-YR GROSS-AREA 6.012 KWH /SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE	=	1.59
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED	=	0.00
HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE	=	6
HOURS ANY ZONE BELOW HEATING THROTTLING RANGE	=	133

M2.0 – Thermostat with Window Switch

	3_MDL00								DOE-	2.2-48z	6/04/20	21 10::	19:08 BD	LRUN 7
REP	ORT- BEPS	Building H	Energy Pe	rformance						WE	ATHER FIL	E- SEATTLE	E BOEING	FI WA
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RES	I ELECTRI MBTU	CITY 56.1	0.0	302.3	426.0	0.0	0.0	0.0	124.0	0.0	0.0	0.0	0.0	908.3
HOU	S ELECTRI MBTU	CITY 133.8	0.0	30.8	108.9	3.7	0.0	0.0	35.4	0.0	0.0	0.0	0.0	312.6
EM1	ELECTRI MBTU	CITY 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FM1	NATURAL MBTU	-GAS 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	MBTU	189.9	0.0	333.1	534.8	3.7	0.0	0.0	159.4	0.0	0.0	0.0	0.0	1221.0
	TOTAL SITE ENERGY1220.96 MBTU29.1 KBTU/SQFT-YR GROSS-AREA29.1 KBTU/SQFT-YR NET-AREATOTAL SOURCE ENERGY1220.96 MBTU29.1 KBTU/SQFT-YR GROSS-AREA29.1 KBTU/SQFT-YR NET-AREAPERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE =3.40PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED=0.00HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE=6HOURS ANY ZONE BELOW HEATING THROTTLING RANGE=292NOTE:ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.													
	2033_MDL00 DOE-2.2-48z 6/04/2021 10:19:08 BDL RUN 7													
203	3_MDLOO			-					DOE-	2.2-48z	6/04/20	21 10::	19:08 BD	LRUN 7
203 REP	3_MDL00 ORT- BEPU	Building T	Jtility P	erformanc	e				DOE-	2.2-48z WE	6/04/20 ATHER FIL	21 10:: E- SEATTLI	19:08 BD E BOEING	LRUN 7 FIWA
203 REP	3_MDLOO ORT- BEPU	LIGHTS	Jtility P TASK LIGHTS	erformanc MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	DOE- VENT FANS	2.2-48z WE REFRIG DISPLAY 	6/04/20 ATHER FIL HT PUMP SUPPLEM	21 10:: E- SEATTLI DOMEST HOT WTR	19:08 BD E BOEING EXT USAGE	L RUN 7 FI WA TOTAL
203 REP 	3_MDLOO ORT- BEPU I ELECTRI KWH	Building U LICHTS CITY 16442.	Utility P TASK LICHTS 	erformanc MISC EQUIP 88565.	SPACE HEATING 124807.	SPACE COOLING 	HEAT REJECT 	PUMPS & AUX 	DOE- VENT FANS 	2.2-48z WE REFRIG DISPLAY 0.	6/04/20 ATHER FIL HT PUMP SUPPLEM 	21 10:: E- SEATTLL DOMEST HOT WTR 0.	19:08 BD E BOEING EXT USAGE 0.	L RUN 7 FI WA TOTAL 266146.
203 REP RES HOU	3_MDL00 ORT- BEPU I ELECTRI KWH S ELECTRI KWH	LIGHTS LIGHTS CITY 16442. CITY 39208.	Utility P TASK LIGHTS 0.	erformanc MISC EQUIP 88565. 9032.	SPACE HEATING 124807. 31903.	SPACE COOLING 	HEAT REJECT 0. 0.	PUMPS & AUX 0.	DOE- VENT FANS 36333. 10365.	2.2-48z WE REFRIG DISPLAY 0. 0.	6/04/20 ATHER FIL HT PUMP SUPPLEM O.	21 10:: E- SEATTLI DOMEST HOT WTR 	19:08 BD E BOEING EXT USAGE 0. 0.	L RUN 7 FI WA TOTAL 266146. 91596.
203 REP RES HOU	3_MDL00 DRT- BEPU I ELECTRI KWH S ELECTRI KWH ELECTRI KWH	LICHTS LICHTS CITY 16442. CITY 39208. CITY 0.	Utility P TASK LIGHTS 0. 0.	erformanc MISC EQUIP 88565. 9032. 0.	SPACE HEATING 124807. 31903. 0.	SPACE COOLING 0. 1087. 0.	HEAT REJECT 0. 0. 0.	PUMPS & AUX 0. 0. 0.	DOE- VENT FANS 36333. 10365. 0.	-2.2-48z WE REFRIG DISPLAY 0. 0. 0.	6/04/20 ATHER FIL HT PUMP SUPPLEM 0. 0. 0.	21 10:: E- SEATTLI DOMEST HOT WTR 0. 0. 0.	19:08 BD E BOEING EXT USAGE 0. 0. 0.	L RUN 7 FI WA TOTAL 266146. 91596. 0.
203: REPI RES HOU: EM1 FM1	3_MDL00 ORT- BEPU I ELECTRI KWH S ELECTRI KWH ELECTRI KWH NATURAL THERM	LIGHTS LIGHTS CITY 16442. CITY 39208. CITY 0. -GAS 0.	Utility P TASK LIGHTS 0. 0. 0. 0.	erformanc MISC EQUIP 88565. 9032. 0. 0.	SPACE HEATING 124807. 31903. 0. 0.	SPACE COOLING 	HEAT REJECT 0. 0. 0. 0.	PUMPS & AUX 0. 0. 0. 0.	DOE- VENT FANS 36333. 10365. 0. 0.	2.2-48z WE REFRIG DISPLAY 0. 0. 0. 0.	6/04/20 ATHER FIL HT PUMP SUPPLEM 0. 0. 0. 0.	21 10:: E- SEATTLI DOMEST HOT WTR 0. 0. 0. 0.	19:08 BD E BOEING EXT USAGE 0. 0. 0. 0.	L RUN 7 FI WA TOTAL 266146. 91596. 0.

HOURS ANY ZONE BELOW HEATING THROTTLING RANGE = 292

P2.0 – Improved Plumbing Distribution

2033_MDL00								DOE-	-2.2-48z	6/04/20	21 10:	19:39 BD	LRUN 8
REPORT- BEPS	Building H	Energy Per	rformance	•					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RESI ELECTRIC MBTU	СІТҮ 56.1	0.0	302.3	535.8	0.0	0.0	0.0	125.2	0.0	0.0	0.0	0.0	1019.3
HOUS ELECTRIC MBTU	133.8	0.0	30.8	107.2	3.7	0.0	0.0	35.4	0.0	0.0	0.0	0.0	310.9
EM1 ELECTRIC MBTU	:ITY 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FM1 NATURAL- MBTU	GAS 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
MBTU	189.9	0.0	333.1	643.0	3.7	0.0	0.0	160.5	0.0	0.0	0.0	0.0	1330.2
	TOT TOT PER(PER(HOU	AL SITE EN AL SOURCE CENT OF HO CENT OF HO RS ANY ZOU	NERGY ENERGY DURS ANY DURS ANY NE ABOVE	1330.25 1330.25 SYSTEM ZO PLANT LOA COOLING T	MBTU MBTU NE OUTSID D NOT SAT HROTTLING	31.7 KBT 31.7 KBT E OF THRO ISFIED RANGE RANGE	U/SQFT-YR U/SQFT-YR TTLING RAI	GROSS-AF GROSS-AF NGE = 0. = 0. =	REA 31 REA 31 .18 .00 .6	7 KBTU/S	QFT-YR NE	T-AREA T-AREA	
	NOTI	E: ENERG	Y IS APPO	NTIONED H	OURLY TO	ALL END-U	SE CATEGO	RIES.	10				
2033_MDL00 REPORT- BEPU	Building (Utility Pe	erformanc	e				DOE-	-2.2-48z WE	6/04/20 ATHER FIL	21 10:: E- SEATTL	19:39 BD E BOEING	LRUN 8 FIWA
				CDACE	CDACE		DIMOS		DEPDIC		DOMESCI		
	LIGHTS	LIGHTS	EQUIP	HEATING	COOLING	REJECT	& AUX	FANS	DISPLAY	SUPPLEM	HOT WTR	USAGE	TOTAL
RESI ELECTRIC KWH	ПТҮ 16442.	0.	88565.	156983.	0.	٥.	0.	36671.	0.	٥.	Ο.	0.	298661.

20	33_MDL00								DOE-	2.2-48z	6/04/20	21 10:	19:39 BD	LRUN 8
RE	PORT- BEPU	Building	Utility F	Performanc	æ					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RE	SI ELECTRIC KWH	CITY 16442.	0.	88565.	156983.	0.	0.	0.	36671.	0.	0.	0.	0.	298661.
HO	US ELECTRIC KWH	CITY 39208.	0.	9032.	31409.	1087.	0.	Ο.	10365.	Ο.	Ο.	Ο.	Ο.	91101.
EM	1 ELECTRIC KWH	CITY 0.	Ο.	0.	Ο.	0.	0.	Ο.	Ο.	Ο.	Ο.	Ο.	Ο.	0.
FM	1 NATURAL- THERM	-GAS 0.	0.	0.	Ο.	0.	0.	0.	0.	0.	Ο.	0.	0.	0.

TOTAL ELECTRICITY 389762. KWH 9.277 KWH /SQFT-YR GROSS-AREA 9.277 KWH /SQFT-YR NET-AREA

	10
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.	00
HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE =	6
HOURS ANY ZONE BELOW HEATING THROTTLING RANGE =	10

Proposed (All Measures Included)

	3_MDL00								DOE-	2.2-48z	6/04/20	21 10:	52:15 BD	L RUN 10
REP	ORT- BEPS	Building [Energy Pe	rformance	•					WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RES	I ELECTRIC MBTU	CITY 56.1	0.0	290.6	19.1	0.0	0.0	16.1	155.3	0.0	0.0	0.0	0.0	537.2
HOU	S ELECTRIC MBTU	CITY 83.3	0.0	30.8	0.4	3.1	0.0	0.0	0.6	0.0	0.0	0.0	0.0	118.2
EM1	ELECTRIC MBTU	CITY 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FM1	NATURAL- MBTU	-GAS 0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	MBTU	139.4	0.0	321.5	19.5	3.1	0.0	16.1	155.9	0.0	0.0	0.0	0.0	655.4
	TOTAL SITE ENERGY655.41 MBTU15.6 KBTU/SQFT-YR GROSS-AREA15.6 KBTU/SQFT-YR NET-AREATOTAL SOURCE ENERGY655.41 MBTU15.6 KBTU/SQFT-YR GROSS-AREA15.6 KBTU/SQFT-YR NET-AREAPERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE =1.62PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED =0.00HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE =5HOURS ANY ZONE BELOW HEATING THROTTLING RANGE =137NOTE:ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.													
203	3_MDL00								DOE-	2.2-48z	6/04/20	21 10:	52:15 BD	L RUN 10
REPO	ORT- BEPU	Building	Utility P	erforman						WE	ATHER FIL	E- SEATTL	E BOEING	FI WA
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
RES	I ELECTRIC KWH	CITY 16442.	0.	85156.	5585.	0.	٥.	4715.	45498.	٥.	٥.	٥.	٥.	157396.
HOLE	S ELECTRIC KWH	24393.	0.	9032.	126.	918.	0.	0.	170.	0.	0.	0.	0.	34639.
HOU:														
EM1	ELECTRIC KWH	CITY 0.	0.	0.	0.	0.	0.	0.	Ο.	0.	0.	0.	0.	Ο.
EM1	ELECTRIC KWH NATURAL- THERM	CITY O. -GAS O.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.